

IEC 61850 Certificate Level A¹

Page 1/2

Prolan Process Control Co. H-2011 Budakalasz, Szentendrei út 1-3 **HUNGARY**

No. 30820134-Consulting 08-1580

For the product: Prolan ProField IED Protocol stack: 1.1.0 Configuration: 1.0.0 Firmware: 1.0.2

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "ProField-PICS 1.1.0", "ProField-MICS 1.0.0", "ProField-TICS 1.0.0" and product's extra information for testing: "ProField-PIXIT 1.1.2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v1.1):

Basic Exchange (19/23)

Data Sets (2/5)

Unbuffered Reporting (12/13)

Buffered Reporting (14/15)

12a Direct Control (5/11)

12b SBO Control (7/15)

12c Enhanced Direct Control (5/11) 12d Enhanced SBO Control (10/17)

13 Time Synchronization (4/4)

This Certificate includes a summary of the test results as carried out at KEMA Consulting in The Netherlands with UniCAsim 61850 version 3.17.03 with test suite 3.17.03 and UniCA 61850 analyzer 4.17.01. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30820134-Consulting 08-1579 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by Prolan Process Control. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, July 18, 2008

W. Strabbing

Manager Intelligent Networks and Communication

S.J.T. Mulder

SeniorTest Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3,	Srv6, Srv7, Srv8,
	AssN4, AssN5	SrvN1e, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5,	
	SrvN1abcd, SrvN4	
2: Data Sets	Dset1, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7	Rp5, RpN5, RpN6
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9	Br5, BrN6
	BrN1, BrN2, BrN3, BrN4, BrN5	
12a: Direct control	CltN3, CtlN8	Ctl2
	DOns1, DOns3	
12b: SBO control	Ctl3, CltN1, CltN2, CtlN3, CltN4	Ctl2
	SBOns2	
12c: Enhanced Direct	CltN3, CtlN8	Ctl2
Control	DOes2, DOes5	
12d: Enhanced SBO	Ctl3, CltN1, CltN2, CltN3, CltN4, CtlN9	Ctl2
control	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	TmN2