

IEC 61850 Certificate Level A¹

Page 1/2

Issued to: SHR Automation 3399 Huaning Road Minhang District Shanghai 201108, China No. 30920410-Consulting 09-1136

For the product: UDC-501 Bay Control Unit Firmware version R2.03

Issued by: KEMA 🔾

The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "PICS_UDC501 version 1.08", "MICS_UDC501 version 1.08", "TICS_UDC501 version 1.08", "TICS_UDC501 version 1.08".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):

- 1 Basic Exchange (19/24)
- 2 Data Sets (3/6)
- 3 Substitution (4/4)
- 4+ Setting Group Definition (10/10)
- 5 Unbuffered Reporting (14/18)
- 6 Buffered Reporting (17/20)

- a GOOSE Publish (7/12)
- 9b GOOSE Subscribe (9/10)
- 12a Direct Control (4/11)
- 12c Enhanced Direct Control (4/13)
- 12d Enhanced SBO Control (11/19)
- 13 Time Synchronization (3/4)
- 14 File Transfer (6/7)

This Certificate includes a summary of the test results as carried out at SHR Automation in China with UniCAsim 61850 version 3.19.01 with test suite 3.19.00 and UniCA 61850 analyzer 4.18.01. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30920410-Consulting 09-1135 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by SHR Automation. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, June 9, 2009

W. Strabbing

Manager Intelligent Networks and Communication

S.J.T. Mulder Senior Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv6, Srv7, Srv8, SrvN1e, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
3: Substitution	Sub1, Sub2, Sub3, SubN1	
4: Setting Group Selection	Sg1, SgN1a	Sg3a
4+: Setting Group Definition	Sg2, Sg3b, Sg4, SgN1b, SgN2, SgN3, SgN4	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10	Rp5, Rp8, Rp9, RpN6
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12	Br5, Br10, Br11, BrN6
	BrN1, BrN2, BrN3, BrN4, BrN5	
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CltN3, CtlN8, DOns1, DOns3	
12c: Enhanced Direct Control	CltN3, CtlN8, DOes2, DOes5	
12d: Enhanced SBO control	Ctl3, CltN1, CltN2, CltN3, CltN4, CtlN9	Ctl7, Ctln11
	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, FtN1ab	Ft2c, Ft4, FtN1c