

IEC 61850 Certificate Level A¹

Page 1/2

Issued to

SystemCORP Embedded Technology Pty Ltd Suite 4/12 Brodie Hall Drive Technology Park Bentley WA 6102 Australia

Issued by:



No. 74100344-MOC/INC 11-0597

For the product:
WebCAN Substation Control and
Monitoring System
With Firmware v1.36.00

The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IEC 61850 SET Protocol Implementation Conformance Statement (PICS) WebCAN, version 4.01", "IEC 61850 SET Model Implementation Conformance Statement (MICS) WebCAN, version 1.02", "IEC 61850 SET TISSUES Implementation Conformance Statement (TICS) WebCAN, version 1.02" and product's extra information for testing: "IEC 61850 SET Protocol implementation extra Information for testing (PIXIT) WebCAN, version 1.05"

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2b):

- 1 Basic Exchange (19/24)
- 2 Data Sets (3/6)
- 5 Unbuffered Reporting (14/18)
- 6 Buffered Reporting (16/20)
- 9a GOOSE Publish (9/12)
- 9b GOOSE Subscribe (9/10)

- 12a Direct Control (6/11)
- 12b SBO Control (8/14)
- 12c Enhanced Direct Control (6/13)
- 12d Enhanced SBO Control (11/19)
- 13 Time Synchronization (3/5)

This Certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCAsim 61850 version 3.21.02 with test suite 3.21.02 and UniCA 61850 analyzer 4.22.02. The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74100344-MOC/INC 11-0596 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by SystemCORP. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 14 April 2011

M. Adriaensen

Regional Director Management & Operations Consulting

Robin Massink Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2b

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv6, Srv7, Srv8, SrvN1e, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10	Rp8, Rp9, RpN5, RpN6
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12	Br10, Br11, BrN6
	BrN1, BrN2, BrN3, BrN4, BrN5	
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop5, Gop6, Gop10, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CltN3, CtlN8	Ctl2, CtlN11
	DOns1, DOns3	
12b: SBO control	Cti3, CltN1, CltN2, CtiN3, CltN4,	Ctl2, CtlN11
	SBOns2	
12c: Enhanced Direct Control	CitN3, CtiN8	Ctl2, CtlN11
	DOes2, DOes5	
12d: Enhanced SBO control	Cti3, CltN1, CltN2, CltN3, CltN4, CtlN9	Ctl2, CtlN11
	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	