



IEC 61850 Certificate Level A¹

Page 1/2

No. 74104514-MOC/INC 13-1787

Issued to:
Yousung Instrument & Electric Co.
#7-13, Songdo-dong, Yeonsu-gu
Incheon
Republic of Korea

For the 92LE publisher:
YSMU-121540
Hardware version 1.0
Firmware version 1.0
Supporting:
3 phase voltage and current
Neutral is either calculated or measured

Issued by:



The 92LE publisher has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-2 and 9-2

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 and the UCAIUG "Test procedures version 1.1 for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2 (9-2LE version 2.1)" with 92LE publisher's protocol implementation conformance statement: "Protocol Implementation Conformance Statement for the IEC 61850 interface in YSMU-121540" and extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in YSMU-121540".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

11a Sampled Value publish (15/17)	60 Hz with 256 samples per cycle
-----------------------------------	----------------------------------

This certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCA 61850 Analyzer 61850 version 5.26.04. This document has been issued for information purposes only, and the original paper copy of the test report: No. 74104514-MOC/INC 13-1788 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by Yousung. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, May 14, 2013

M. Adriaansen
Director Intelligent Networks & Communication

R. Schimmel
Certification Manager

1 Level A - Independent Test lab with certified ISO 9001 quality system

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.

KEMA Nederland B.V.
Utrechtseweg 310, 6812 AR Arnhem P.O.Box 9035, 6800 ET Arnhem The Netherlands
T +31 26 356 61 42 F +31 26 351 36 83 sales@kema.com www.kema.com



Applicable test procedures from the UCAIUG: Test procedures version 1.1 for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2 (9-2LE version 2.1)"

Conformance Block	Mandatory	Conditional
Configuration	Cnf1, Cnf2, Cnf3, Cnf4, Cnf5, Cnf6, Cnf7, Cnf8	
11a Sampled Value Publishing 60Hz, 256 samples/cycle	Svp1, Svp2, Svp3, Svp6, Svp10, Svp11, Svp14, Svp15	Svp5, Svp7, Svp9, Svp12, Svp13, Svp16, Svp17