



# IEC 61850 Certificate Level A<sup>1</sup>

No. 74101720-MOC/INC 12-01154

Issued to:  
LS Industrial Systems  
1 Songjeong-dong  
Cheongju-si  
Chungbuk-do  
Republic of Korea

For the product:  
GIPAM-DL  
Multifunctional protection, measurement  
and control device  
Communication Software v1.02 04.18



The product has not shown to be non-conforming to:  
**IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: Protocol Implementation Conformance Statement for the IEC 61850 interface in GIPAM-DL (Rev2), Model Implementation Conformance Statement for the IEC 61850 interface in GIPAM-DL(Rev2), TISSUES Implementation Conformance Statement for the IEC 61850 interface in GIPAM\_DL (Rev1), and product's extra information for testing: Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in GIPAM-DL (Rev3)

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2b):

1	Basic Exchange (20/24)	9a	GOOSE Publish (6/12)
2	Data Sets (3/6)	9b	GOOSE Subscribe (10/10)
2+	Data Set Definition (23/23)	12a	Direct Control (6/11)
4	Setting Group Selection (3/3)	12d	Enhanced SBO Control (13/19)
5	Unbuffered Reporting (15/18)	13	Time Synchronization (5/5)
6	Buffered Reporting (17/20)	14	File Transfer (4/7)

This certificate includes a summary of the test results as carried out at KEMA in The Netherlands with UniCasim 61850 version 3.25.03 with test suite v3.24.02b and UniCA 61850 analyzer 4.24.02. The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 12-01153 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by LS Industrial Systems. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, June 18, 2012

M. Adriaansen  
Intelligent Networks and Communication

G. Akse  
Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2b

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5  Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9  DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
4: Setting Group Selection	Sg1, SgN1a	Sg3
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10  RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12  BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct control	CtlN3, CtlN8  DOns1, DOns3	Ctl2, CtlN11
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9  SBOes1, SBOes2, SBOes3	Ctl2, Ctl7, CtlN6, CtlN11
13: Time sync	Tm1, Tm2, TmN1	Tm3, TmN2
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	