



# IEC 61850 Certificate Level A<sup>1</sup>

No. 74100457-MOC/INC 13-0779

Issued to:  
ALSTOM GRID UK Ltd.  
St. Leonards Avenue  
Stafford ST17 4LX  
United Kingdom

For the server product:  
MiCOMho P443  
Fast Multifunctional Distance Protection  
Relay  
Software version 71C  
Hardware version M



The server product has not shown to be non-conforming to:  
**IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
**Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL<sup>2</sup> version 1.5, the product's protocol, model and technical issue implementation conformance statements: "MiCOM Px4x PICS Protocol Implementation Conformance Statement, version A", "MiCOMho P443 MICS Model Implementation Conformance Statement, version 71M" and "MiCOMho P443 TICS Tissues Implementation Conformance Statement, version 71M" and the extra information for testing: "MiCOMho P443 PIXIT Protocol Implementation eXtra Information for Testing for the IEC 61850 interface in P443 with Software Version 71".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (18/24)	12a	Direct Control (5/12)
2	Data Sets (3/6)	12b	SBO Control (7/14)
4	Setting Group Selection (2/3)	12c	Enhanced Direct Control (5/13)
5	Unbuffered Reporting (16/19)	12d	Enhanced SBO Control (10/19)
6	Buffered Reporting (18/21)	13	Time Synchronization (3/5)
9a	GOOSE Publish (10/13)	14	File Transfer (6/7)
9b	GOOSE Subscribe (10/11)		

This certificate includes a summary of the test results as carried out at KEMA in Netherlands with UniCA 61850 client simulator version 4.26.04 with test suite 3.26.00 and UniCA 61850 analyzer 5.26.03. This document has been issued for information purposes only, and the original paper copy of the KEMA report No. 74100457-MOC/INC 13-0778 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by ALSTOM GRID. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, February 26, 2013

M. Adriaansen  
Director Intelligent Networks & Communication

R. Schimmel  
Certification Manager

- 1 Level A - Independent test lab with certified ISO 9001 quality system
- 2 TPCL - test procedures change list

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp8, Rp9, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10, Br11, BrN6
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop10a	Gop1, Gop5, Gop6, Gop10b, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct control	CtiN3, CtiN8, DOns1, DOns3	CtiN11
12b: SBO control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, SBOs2	CtiN11
12c: Enhanced Direct Control	CtiN3, CtiN8, DOes2, DOes5	CtiN11
12d: Enhanced SBO control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, CtiN9 SBOes1, SBOes2, SBOes3	CtiN11
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c