



IEC 61850 Certificate Level A¹

No. 74104768-MOC/INC 13-2854

Issued to:
Bilfinger Mauell GmbH
Am Rosenhügel 1-7
42553 Velbert
Germany

For the server product:
ME 4012 PA-N
V02.10.10.00

Issued by:



The server product has not shown to be non-conforming to:
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL² version 1.5, the product's protocol, model and technical issue implementation conformance statements: Protocol Implementation Conformance Statement for the IEC 61850 interface in VE000 NV01", "Model Implementation Conformance Statement for the IEC 61850 interface in IED of type <VE000 NV01>, software version 02.10.10.00" and "TISSUES Implementation Conformance Statement for the IEC 61850 interface in VE000 NV01" and the extra information for testing: "Protocol Implementation eXtra Information for Testing for the IEC 61850 interface in VE000 NV01".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (21/24)	9a	GOOSE Publish (12/13)
2	Data Sets (3/6)	9b	GOOSE Subscribe (11/11)
2+	Data Set Definition (23/23)	12a	Direct Control (8/12)
3	Substitution (4/4)	12b	SBO Control (10/14)
4	Setting Group Selection (3/3)	12c	Enhanced Direct Control (8/13)
4+	Setting Group Definition (7/7)	12d	Enhanced SBO Control (13/19)
5	Unbuffered Reporting (18/19)	13	Time Synchronization (4/5)
6	Buffered Reporting (20/21)		

This certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCA 61850 Client simulator 4.27.04 with test suite 3.27.00 and UniCA 61850 Analyzer 5.26.04. This document has been issued for information purposes only, and the original paper copy of the KEMA report No. 74104768-MOC/INC 13-2853 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by Bilfinger Mauell GmbH. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, August 15, 2013


M. Adriaansen
Director Intelligent Networks & Communication


R. Schimmel
Certification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
3: Substitution	Sub1, Sub2, Sub3, SubN1	
4: Setting Group Selection	Sg1, SgN1a	Sg3
4+: Setting Group Definition	Sg2, Sg4, SgN1b, SgN2, SgN3, SgN4, SgN5	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, Rp11, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11, Br13, BrN6
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop10a	Gop1, Gop5, Gop6, Gop8, Gop9, Gop10b, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct control	CtiN3, CtiN8 DOns1, DOns3	Cti2, Cti7, CtiN10, CtiN11
12b: SBO control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, SBOns2	Cti2, Cti7, CtiN10, CtiN11
12c: Enhanced Direct Control	CtiN3, CtiN8 DOes2, DOes5	Cti2, Cti7, CtiN10, CtiN11
12d: Enhanced SBO control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, CtiN9 SBOes1, SBOes2, SBOes3	Cti2, Cti7, CtiN10, CtiN11
13: Time sync	Tm1, Tm2, TmN1	Tm3