



IEC 61850 Certificate

Level A¹



Product Service

No. ZE 14 11 90467 001D

Issued to:

Thytronic S.p.A
 Piazza Mistral 7
 20139 Milano
 Italy

For the server product:

PRO-NVA100X-D
 Protection Device
 1.30

Issued by:

TÜV SÜD Product Service GmbH
Communication Protocols
 Barthstrasse 16
 D-80339 Munich
 Germany

Certification Mark:



This certification mark can only be used for the product defined above.

The server product has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations.


The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Test Procedures version 2.3 with TPCL² version 1.7.1, the product's protocol, model and technical issue implementation conformance statements: "PICS for the IEC 61850 interface in <PRO-NVA100X-B>", "MICS for the IEC 61850 interface in <PRO-NVA100X-B>", "TICS for the IEC 61850 interface in <PRO-NVA100X-B>" and the extra information for testing: "PIXIT for the IEC 61850 interface in <PRO-NVA100X-B>".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (23/24)	9a GOOSE Publish (8/13)
2 Data Sets(3/6)	9b GOOSE Subscribe (11/11)
2+ Data Set Definition (23/23)	12a Direct Control (4/12)
5 Unbuffered Reporting (16/19)	12b SBO Control (6/14)
6 Buffered Reporting (18/21)	12d Enhanced SBO Control (10/19)
	13 Time Synchronization (4/5)
	14 File Transfer (4/7)

This certificate includes a summary of the test results as carried out at TÜV SÜD Product Service GmbH in Germany with SimFlex CS version 3.1 with test suite version 3.0.t10 and Wireshark version 1.10.7. This document has been issued for information purposes only, and the original paper copy of the TÜV SÜD Product Service GmbH test report: No. 713037428-TR01-D, version 1.0 will prevail.

Munich, Nov. 19, 2014


 Peter Pfisterer
 Technical Certifier


 Albi Kospiri
 Test Engineer

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

1 Level A - Independent Test lab with certified ISO 17025 Quality System
 2 TPCL - Test procedures change list



Product Service

No. ZE 14 11 90467 001D

Applicable Test Procedures from the UCA International Users Group Server Test Procedures version 2.3 with TPCL version 1.7.1:

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN6 Srv6, Srv7, Srv8, Srv9, Srv10, SrvN1e, SrvN1f, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, RpN5,
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7, Gop9, Gop10a	Gop1, Gop10b
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct control	CtIN3, CtIN8 DOs1	DOs3
12b: SBO control	CtI3, CtIN1, CtIN2, CtIN3, CtIN4, SBOs2	
12d: Enhanced SBO control	CtI3, CtIN1, CtIN2, CtIN3, CtIN4, CtIN9 SBOes1, SBOes2, SBOes3	CtIN6
13: Time sync	Tm1, Tm2	Tm3, TmN1
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	

Zertifiziervertrag

Grundlage für die Zertifikatserteilung ist die Prüf- und Zertifizierungsordnung von TÜV SÜD Product Service.

Mit Erhalt des Zertifikates erkennt der Zertifikatsinhaber die jeweils gültige Fassung der Prüf- und Zertifizierungsordnung an (www.tuev-sued.de/ps_regulations) und wird somit Partner im Zertifiziersystem von TÜV SÜD Product Service.

Prinzipielle Voraussetzung für die Gültigkeit des Zertifikates:

– Gültigkeit der zitierten normativen Prüfgrundlage(n) ist gegeben

und zusätzlich bei Zertifikaten mit Berechtigung zur Verwendung eines Prüfzeichens bzw. bei Zertifikaten für QM-Systeme:

– Voraussetzungen für vorschriftsmäßige Fertigung werden eingehalten.

– Die Fertigungs- bzw. Betriebsstätten werden regelmäßig überwacht.

Certification contract

Certification is based on the TÜV SÜD Product Service Testing and Certification Regulations.

On receipt of the certificate the certificate holder agrees to the current version of the Testing and Certification Regulations (www.tuev-sued.de/ps_regulations) and thus becomes partner in the TÜV SÜD Product Service Certification System.

Requirements for the validity of the certificate in principle:

– Validity of the quoted test standard(s)

In addition for certificates with the right to use a certification mark and for QM certificates:

– Conditions for an adequate manufacturing are maintained

– Regular surveillance of the facility is performed

Akkreditierungen / Benennungen (Status 25.02.2010) /
Accreditations / notifications (as of 2010-02-25)

Deutschland / Germany

Geräte- und Produktsicherheitsgesetz (GPSG) /
Equipment and Product Safety Act (GPSG)

Europa / Europe

- Niederspannungsrichtlinie 2006/95/EG
- Spielzeugrichtlinie 2009/48/EG
- Richtlinie für aktive medizinische Implantate 90/385/EWG
- Richtlinie für Medizinprodukte 93/42/EWG
- Richtlinie für In-vitro-Diagnostika 98/79/EG
- Richtlinie für Gasverbrauchseinrichtungen 90/396/EWG
- Richtlinie für persönliche Schutzausrüstungen 89/686/EWG
- EMV-Richtlinie 2004/108/EG
- Richtlinie für Sportboote 94/25/EG + 2003/44/EG
- Richtlinie für Maschinen 2006/42/EG
- Richtlinie für Ex-Schutz Geräte 94/9/EG

- Low Voltage Directive 2006/95/EC
- Toys Directive 2009/48/EC
- Directive for Active Implantable Medical Devices 90/385/EEC
- Directive for Medical Devices 93/42/EEC
- Directive on In Vitro Diagnostic Medical Devices 98/79/EC
- Directive for Gas Appliances 90/396/EEC
- Directive for Personal Protective Equipment 89/686/EEC
- EMC Directive 2004/108/EC
- Directive for Recreational Craft 94/25/EC + 2003/44/EC
- Directive for Machinery 2006/42/EC
- Directive for Ex Safe Equipment 94/9/EC

- ENEC Agreement for luminaires and IT equipment

USA

- Nationally Recognized Testing Laboratory (NRTL) to 29 CFR 1910.7 by OSHA
- Accredited for FDA 510(k) Third Party Review
- Conformity Assessment Body to the MRA for Medical Devices; FDA QSR Reg Inspections, FDA 510(k) Third Party Review

Asien-Pazifik Region / Asia Pacific

- Recognized Certification Body to Electrical Products (Safety) Regulation; Hong Kong
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Australien / Australia
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Neuseeland / New Zealand

Weltweit / Worldwide

- NCB im CB-Scheme des IECEE / NCB in the CB Scheme of IECEE
- ExCB im IECEX-Scheme des IECEE / ExCB in the IECEX Scheme of IECEE
- TÜV SÜD Product Service Mark für Produkte / TÜV SÜD Product Service Mark for products DAP-ZE-1213.00
- Zertifizierung von QMS / Certification of QMS TGA-ZM-08-93-00
- Zertifizierung von QMS gemäß / Certification of QMS according to (DIN) EN ISO 13485 / ISO 13485