



# IEC 61850 Certificate Level B<sup>1</sup>

No. 2009PUCA0005

Issued to:  
Shanghai Sunrise Power Tech (Group) Co., Ltd.  
1881, Laiyin Road, SongJiang Hi-tech Park,  
Shanghai, China

For the product:  
DEP-500N Protection and Control Device  
Software Version 2.0

Issued by: **KETOP** 开普

## The product has not shown to be non-conforming to: **IEC 61850-7-1, 7-2, 7-3, 7-4 and 8-1** Communication networks and systems in substations.

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and TISSUE implementation conformance statements: "DEP-500N Protection and Control Device PICS", "DEP-500N Protection and Control Device MICS", "DEP-500N Protection and Control Device TICS", and extra information "DEP-500N Protection and Control Device PIXIT" for testing.

The following IEC 61850 conformance blocks are tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test Procedures):

|                                   |                                    |
|-----------------------------------|------------------------------------|
| 1 Basic Exchange (21/24)          | 12a Direct control (5/11)          |
| 2 Data Sets (4/6)                 | 12c Enhanced Direct Control (5/13) |
| 2+ Data Set Definition (23/23)    | 12d Enhanced SBO control (10/19)   |
| 4 Setting Group Selection (3/3)   | 13 Time sync (3/5)                 |
| 4+ Setting Group Definition (6/6) | 14 File transfer (6/7)             |
| 5 Unbuffered Reports (14/18)      |                                    |
| 6 Buffered Reporting (16/20)      |                                    |

KETOP Lab grants this Certificate on account of tests performed at the KETOP Lab's offices in Xuchang, China, with UniCASim 61850 version 3.16.00 test system with test suite 3.16.03 simulating an IEC 61850 client and the UniCA 61850 analyzer Version 4.17.01. The tests are based on the UCA International Users Group Device Test Procedure Version 2.2. This certificate has been issued for information purposes only and the original copy of the KETOP Lab report: No. JW090010 will prevail.

The tests have been carried out on one single specimen of the above-mentioned products, submitted by Shanghai Sunrise. The certificate does not include an assessment of the manufacturer's production process. Conformity of his production process or any other product than the specimen tested by KETOP Lab is not the responsibility of KETOP Lab.

Xuchang, December 18, 2009

He Chun  
General Engineer KETOP Lab

Zhang Ran  
Test Engineer

<sup>1</sup> Level B – Tester with ISO 9000 or ISO 17025 Quality System

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

**China KETOP Lab ( Xuchang KETOP Electrical Apparatus Testing & Research Institute )  
National Center For Quality Supervision & Testing of Relay Protection and Automation Equipment**

1706#, Xuji Avenue, XuChang, Henan, P.R.China, P.C. 461000  
T +86 374 3212755 F +86 374 3212775 www.ketop.cn



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

| <b>Conformance Block</b>                        | <b>Mandatory</b>   | <b>Conditional</b>                                  |
|---|--|---|
| 1: Basic Exchange                               | Ass1, Ass2, Ass3, AssN2, AssN3,<br>AssN4, AssN5<br>Srv1, Srv2, Srv3, Srv4, Srv5,<br>SrvN1abcd, SrvN4   | Srv9, Srv10,<br>Srv8, SrvN1f<br>Srv6, SrvN1e, SrvN3 |
| 2: Data Sets                                    | Dset1, Dset10a, DsetN1ae   | Dset10b   |
| 2+: Data Set Definition<br>(SCL-DynDataSet)     | Dset2, Dset3, Dset4, Dset5, Dset6,<br>Dset7, Dset8, Dset9<br>DsetN1cd, DsetN2, DsetN3, DsetN4,<br>DsetN5, DsetN6, DsetN7, DsetN8,<br>DsetN9, DsetN10, DsetN11, DsetN12,<br>DsetN13, DsetN14, DsetN15 |   |
| 4: Setting Group Selection<br>(SCL-ConfSG)      | Sg1, SgN1a   | Sg3   |
| 4+: Setting Group<br>Definition<br>(SCL-SGEdit) | Sg2, Sg4<br>SgN1b, SgN2, SgN3, SgN4  |   |
| 5: Unbuffered Reporting                         | Rp1, Rp2, Rp3, Rp4, Rp7, Rp10<br>RpN1, RpN2, RpN3, RpN4  | Rp6, RpN5<br>Rp8, Rp9                               |
| 6: Buffered Reporting                           | Br1, Br2, Br3, Br4, Br7, Br8, Br9,<br>Br12<br>BrN1, BrN2, BrN3, BrN4, BrN5   | Br6, Br10<br>Br11                                   |
| 12a Direct control                              | CtlN3, CtlN8<br>DOns1, DOns3   | CtlN11  |
| 12c Enhanced Direct<br>Control                  | CtlN3, CtlN8<br>DOes2, DOes5   | CtlN11  |
| 12d Enhanced SBO<br>control                     | Ctl3, CtlN1, CtlN2, CtlN3, CtlN4,<br>CtlN9<br>SBOes1, SBOes2, SBOes3   | CtlN11  |
| 13 Time sync                                    | Tm1, Tm2, TmN1   |   |
| 14 File transfer                                | Ft1, Ft2ab, Ft4, FtN1ab  | Ft2c, FtN1c   |