



IEC 61850 Certificate Level A¹



Product Service

No. ZE 14 12 69469 002

Issued to:

Maschinenfabrik Reinhausen GmbH
Falkensteinstr. 8
93059 Regensburg

For the server product:

TAPCON®
Voltage Regulator Unit
Firmware v. 2.36

Issued by:

TÜV SÜD Product Service GmbH
Communication Protocols
Barthstrasse 16
D-80339 Munich
Germany

Certification Mark:



This certification mark can only be used for the product defined above.

**The server product has not been shown to be non-conforming to:
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems for power utility automation.**

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with the product's protocol, model and technical issue implementation conformance statements: "PICS for the IEC 61850 interface in TAPCON®", "MICS for the IEC 61850 interface in TAPCON®", "TICS for the IEC 61850 Ed2 interface in TAPCON®" and product's extra information for testing: "PIXIT for the IEC 61850 interface in TAPCON®".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (22/26)	12a Direct Control (6/20)
2 Data Sets(3/6)	13 Time Synchronization (5/7)
2+ Data Set Definition (22/24)	
5 Unbuffered Reporting (19/20)	

This certificate includes a summary of the test results as carried out at Munich in Germany with SimFlex CS Ed.3 1.0b with test suite 1.0.t1-EA05 and Wireshark 1.10.3. This document has been issued for information purposes only, and the original paper copy of the TÜV SÜD Product Service GmbH test report: No. 713041810-TR01, version 1.0 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to TÜV SÜD Product Service GmbH by Maschinenfabrik Reinhausen GmbH. The manufacturer's production process has not been assessed. This certificate does not imply that TÜV SÜD Product Service GmbH has certified or approved any product other than the specimen tested.

Munich, 2014-12-18

Maurizio Scavazon
Technical Certifier

Albi Kospiri
Test Engineer

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

1 Level A - Independent Test lab with certified ISO 17025 Quality System



Product Service

No. ZE 14 12 69469 002

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0:

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrvN1e, sSrvN1f, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs12, sDs13, sDs14, sDsN1cd sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp8, sRp9, sRp10, sRp11, sRp12, sRp14, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp5, sRp6, sRp7, sRpN5
12a Direct control	sCtl5, sCtl10, sCtl14, sDOns1, sDOns2	sCtl16
13 Time sync	sTm1, sTm2, sTmN1	sTm3, sTmN2

Zertifizierungsvertrag

Grundlage für die Zertifikatserteilung ist die Prüf- und Zertifizierungsordnung von TÜV SÜD Product Service.

Mit Erhalt des Zertifikates erkennt der Zertifikatsinhaber die jeweils gültige Fassung der Prüf- und Zertifizierungsordnung an (www.tuev-sued.de/ps_regulations) und wird somit Partner im Zertifiziersystem von TÜV SÜD Product Service.

Prinzipielle Voraussetzung für die Gültigkeit des Zertifikates:

- Gültigkeit der zitierten normativen Prüfgrundlage(n) ist gegeben
- und zusätzlich bei Zertifikaten mit Berechtigung zur Verwendung eines Prüfzeichens bzw. bei Zertifikaten für QM-Systeme:
- Voraussetzungen für vorschriftsmäßige Fertigung werden eingehalten.
- Die Fertigungs- bzw. Betriebsstätten werden regelmäßig überwacht.

Certification contract

Certification is based on the TÜV SÜD Product Service Testing and Certification Regulations.

On receipt of the certificate the certificate holder agrees to the current version of the Testing and Certification Regulations (www.tuev-sued.de/ps_regulations) and thus becomes partner in the TÜV SÜD Product Service Certification System.

Requirements for the validity of the certificate in principle:

- Validity of the quoted test standard(s)
- In addition for certificates with the right to use a certification mark and for QM certificates:
- Conditions for an adequate manufacturing are maintained
- Regular surveillance of the facility is performed

Akkreditierungen / Benennungen (Status 25.02.2010) /
Accreditations / notifications (as of 2010-02-25)

Deutschland / Germany

Geräte- und Produktsicherheitsgesetz (GPSG) /
Equipment and Product Safety Act (GPSG)

Europa / Europe

- Niederspannungsrichtlinie 2006/95/EG
- Spielzeugrichtlinie 2009/48/EG
- Richtlinie für aktive medizinische Implantate 90/385/EWG
- Richtlinie für Medizinprodukte 93/42/EWG
- Richtlinie für In-vitro-Diagnostika 98/79/EG
- Richtlinie für Gasverbrauchseinrichtungen 90/396/EWG
- Richtlinie für persönliche Schutzausrüstungen 89/686/EWG
- EMV-Richtlinie 2004/108/EG
- Richtlinie für Sportboote 94/25/EG + 2003/44/EG
- Richtlinie für Maschinen 2006/42/EG
- Richtlinie für Ex-Schutz Geräte 94/9/EG

- Low Voltage Directive 2006/95/EC
- Toys Directive 2009/48/EC
- Directive for Active Implantable Medical Devices 90/385/EEC
- Directive for Medical Devices 93/42/EEC
- Directive on In Vitro Diagnostic Medical Devices 98/79/EC
- Directive for Gas Appliances 90/396/EEC
- Directive for Personal Protective Equipment 89/686/EEC
- EMC Directive 2004/108/EC
- Directive for Recreational Craft 94/25/EC + 2003/44/EC
- Directive for Machinery 2006/42/EC
- Directive for Ex Safe Equipment 94/9/EC

- ENEC Agreement for luminaires and IT equipment

USA

- Nationally Recognized Testing Laboratory (NRTL) to 29 CFR 1910.7 by OSHA
- Accredited for FDA 510(k) Third Party Review
- Conformity Assessment Body to the MRA for Medical Devices; FDA QSR Reg Inspections, FDA 510(k) Third Party Review

Asien-Pazifik Region / Asia Pacific

- Recognized Certification Body to Electrical Products (Safety) Regulation; Hong Kong
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Australien / Australia
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Neuseeland / New Zealand

Weltweit / Worldwide

- NCB im CB-Scheme des IECEE / NCB in the CB Scheme of IECEE
- ExCB im IECEX-Scheme des IECEE / ExCB in the IECEX Scheme of IECEE
- TÜV SÜD Product Service Mark für Produkte / TÜV SÜD Product Service Mark for products DAP-ZE-1213.00
- Zertifizierung von QMS / Certification of QMS TGA-ZM-08-93-00
- Zertifizierung von QMS gemäß / Certification of QMS according to (DIN) EN ISO 13485 / ISO 13485