

# IEC 61850 Certificate Level A<sup>1</sup>

Ref. No: 2017TS01167

Issued to:  
**Rootech, Inc.**  
102-611 Digital Empire2,  
88, Sin won-ro, Yeongtong-gu, Suwon,  
Gyeonggi-do, 16681  
Republic of Korea

For the server product:  
**Accura2700M**  
**Motor Management System**  
**Application Version E1.0.0**

Issued by:  
**Korea Electrotechnology Research Institute**  
111, Hanggaul-ro, Sangnok-gu, Ansan-si, Gyeonggi-do, 15588, Republic of Korea

The server product has not been shown to be non-conforming to:  
**IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
**Communication networks and systems for power utility automation.**

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL<sup>2</sup> version 1.2 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in Accura2700M, v1.0", "Model Implementation Conformance Statement for the IEC 61850 interface in Accura2700M, v1.0", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in Accura2700M, v1.0" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in Accura2700M, v1.0".

The following IEC 61850 conformance blocks are tested with a positive result (number of relevant and executed test cases / total number of test cases) :


1	Basic Exchange (20/26)	12a	Direct Control (6/18)
2	Data Sets (4/7)	12b	SBO Control (11/27)
2+	Data Set Definition (24/24)	12c	Enhanced Direct Control (8/20)
5	Unbuffered Reports (20/21)	12d	Enhanced SBO Control (12/28)
6	Buffered Reports (27/30)	13	Time Synchronization (4/7)

This Certificate includes a summary of the test results as carried out at KERI in Republic of Korea with UniCA 61850 Client simulator version 4.29.03 with test suite Ed2 3.28.05(TPCL 1.2) and UniCA 61850 analyzer version 5.31.00. This document has been issued for information purposes only, and the original paper copy of the KERI report: 2017TS01167 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KERI by Rootech, Inc. The manufacturer's production process has not been assessed. This Certificate does not imply that KERI has approved any product other than the specimen tested

Republic of Korea, April 26, 2017

Y. J. Lee  
Executive Director  
Power Apparatus Testing and Evaluation Division



J. I. Jeong  
Technical Manager



<sup>1</sup> Level A – Independent Tester with certified ISO 17025 Quality System

<sup>2</sup> TPCL – Test procedures change list

## Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL version 1.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sSrv6, sSrv8, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Sets Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl13, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl16, sCtl27
12c: Enhanced Direct control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl13, sCtl14, sCtl16, sCtl26
12d: Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTmN2