

IEC 61850 Certificate Level A¹

No. 10077187-INC 18-2151

Issued to:

Schneider Electric
Recloser Solutions
80 Schneider Road
Eagle Farm, Brisbane
QLD 4009, Australia

For the server product:

ADVC3 - Advanced Controller
Firmware version: A50-05.00r29189
S/N: 000006

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.2.4 with product's protocol, model and technical issue implementation conformance statements: "ADVC3 Advanced Controller Range PICS, version 1.0", "ADVC3 Advanced Controller Range MICS, version 1" and "ADVC3 Advanced Controller Range TICS, version 1.0" and the extra information for testing: "ADVC3 Advanced Controller Range PIXIT, version 1.0".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (21/26)	12a Direct Control (5/18)
2 Data Sets (4/7)	12d Enhanced SBO Control (12/28)
2+ Data Set Definition (24/24)	13 Time Synchronization (4/7)
5 Unbuffered Reporting (20/21)	
6 Buffered Reporting (27/30)	

This certificate includes a summary of the test results as carried out at Schneider Electric in Australia, with Unigrd SA 1.4 with test suite Ed2 1.0.56 and UniCA 61850 Analyzer 5.34.01. This document has been issued for information purposes only, and the original paper copy of the DNV GL verification report No. 10077187-INC 18-2153 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Schneider Electric. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, February 20, 2018



E. Henríquez Suarez
Business Leader
Intelligent Networks and Communication

Issued by:



DNV-GL
DNV KEMA is now DNV GL



R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.4

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl16
13: Time sync	sTm1, sTm2, sTmN1	sTm5