

IEC 61850 Certificate Level A¹

No. 10147682-INC 19-2436

Issued to:

Ametek Power Instruments 255 North Union Street Rochester, NY 14605 USA

For the server product:

TR-3000 Multi-Function Recorder Software version: 2.0.0

S/N: 18400001

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in AMETEK TR3000, version 1.9", "Model Implementation Conformance Statement for the IEC 61850 interface in AMETEK TR3000, version 2.0.0" and "TISSUES Implementation Conformance Statement for the IEC 61850 Ed2 interface in AMETEK TR3000, version 2.0.0" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in AMETEK TR3000, revision 13".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| - | D:- | Exchange | (20/20) |
|---|-------|----------|------------|
| | Basic | Exchange | 1 /11/ /51 |
| | | | |

- 2 Data Sets (4/7)
- 5 Unbuffered Reporting (20/21)
- 6 Buffered Reporting (27/30)

- 9a GOOSE Publish (10/13)
- 9b GOOSE Subscribe (13/14)
- 13 Time Synchronization (3/7)
- 14 File Transfer (6/8)

This certificate includes a summary of the test results as carried out at DNV GL in The Netherlands with UniGrid SA Simulator 1.4.453 with test suite 1.0.49 and UniCA 61850 Analyzer 5.34.02. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10147682-INC 19-2435 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Ametek. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, April 29, 2019

E. Henriquez

Business Leader

Interoperability of Smart Power Systems

Issued by:



DNV KEMA is now DNV GL

R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.



IEC 61850 Certificate Level A

No. 10147682-INC 19-2436

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

| Conformance Block | | Mandatory | Conditional |
|-------------------|-------------------------|--|--|
| 1: | Basic Exchange | sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4 | sAssN6, sSrv6, sSrv8, sSrvN1e, sSrvN1f, sSrvN2 |
| 2: | Data Sets | sDs1, sDs10a, sDsN1ae | sDs15 |
| 5: | Unbuffered Reporting | sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8 | sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRpN5 |
| 6: | Buffered Reporting | sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8 | sBr6, sBr7, sBr8, sBr10, sBr11, sBr12 |
| 9a: | GOOSE publish | sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11 | sGop1, sGop6, sGop7, sGopN1 |
| 9b: | GOOSE subscribe | sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6 | sGos4 |
| 13: | Time sync | sTm1, sTm2, sTmN1 | |
| 14: | File transfer | sFt1, sFt2ab, sFt4, sFt5, sFtN1ab | sFt3 |