

No. 10164705-INC 19-2720

**Issued to:**

Elspec Engineering Ltd.  
4 Hashoham St. Zone 23  
Caesarea Industrial Park  
3088900 Israel

**For the 9-2LE publisher:**

G5 Digital Fault Recorder  
Software version: 1.0.2.18  
S/N: 00-17-EB-26-B0-68  
Supporting:  
4 phase voltage and current  
Neutral is measured

The 9-2LE publisher has not been shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-2, and 9-2

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 and the UCA International Users Group "Test Procedures version 1.1 for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2 (9-2LE version 2.1)" with TPCL<sup>2</sup> version 1.1 with 9-2LE publisher's protocol implementation conformance statement: "Protocol Implementation Conformance Statement for the IEC 61850 interface in G5 DFR, version 1.1" and extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in G5 DFR, version 2.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

11a Sampled Value publish (13/17)	50 Hz with 80 samples per cycle
11a Sampled Value publish (13/17)	60 Hz with 80 samples per cycle

This certificate includes a summary of the test results as carried out at DNV GL in the Netherlands with UniCA 61850 Analyzer version 5.36.01. This document has been issued for information purposes only, and the archived DNV GL report No. 10164705-INC 19-2719 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Elspec. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, August 2, 2019



**N.A. Heijker**  
Business Leader  
Interoperability of smart power systems

**Issued by:**



**DNV-GL**  
DNV KEMA is now DNV GL



**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

<sup>2</sup> TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Test procedures version 1.1 for Sampled Values Publishers according to the "Implementation Guideline for Digital Interface to Instrument Transformers using IEC 61850-9-2 (9-2LE version 2.1)" with TPCL version 1.1.

<b>Conformance Block</b>	<b>Mandatory</b>	<b>Conditional</b>
Configuration	Cnf1, Cnf2, Cnf3, Cnf4, Cnf5, Cnf6, Cnf7, Cnf8	
11a Sampled Value Publishing 50 Hz, 80 samples/cycle	Svp1, Svp2, Svp3, Svp6, Svp10, Svp11, Svp14	Svp4, Svp7, Svp8, Svp12, Svp13, Svp15
11a Sampled Value Publishing 60Hz, 80 samples/cycle	Svp1, Svp2, Svp3, Svp6, Svp10, Svp11, Svp14	Svp4, Svp7, Svp8, Svp12, Svp13, Svp15