

No. 10160572-INC 19-2942

Issued to:

Beijing SIFANG Automation Co., Ltd.
No.9, Shangdi Fourth Street
Haidian District
Beijing 100085
Peoples Republic of China

For the server product:

CSC-150-EBL
Centralized Busbar Protection IED
Software version: V1.40
Hardware version: 8SF.004.520/V2
S/N: SFJB400005251519000001

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev1 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for the IEC 61850 interface in CSC and CSI devices, v.1.00", "Model Implementation Conformance Statement (MICS) for the IEC 61850 interface in CSC-150-EBL, v2.00" and "TISSUES Implementation Conformance Statement (TICS) for the IEC Edition 2 61850 Server interface in CSC and CSI devices, v1.00" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Edition 2 server interface in CSC and CSI devices, v1.00".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (23/28)	9a GOOSE Publish (9/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (16/18)
2+ Data Set Definition (22/24)	12a Direct Control (5/17)
3 Substitution (3/3)	12d Enhanced SBO Control (11/27)
4 Setting Group Selection (4/4)	13 Time Synchronization (5/7)
4+ Setting Group Definition (13/13)	14 File Transfer (5/8)
5 Unbuffered Reporting (20/22)	15 Service Tracking (4/17)
6 Buffered Reporting (30/32)	

This certificate includes a summary of the test results as carried out at DNV GL in The Netherlands with UniGrid SA Simulator 1.6.4 with test suite 1.0.21 and UniCA 61850 Analyzer 5.34.02. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10160572-INC 19-2941 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Beijing Sifang. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, November 29, 2019



N.A. Heijker
Business Leader
Interoperability of Smart Power Systems

Issued by:



DNV-GL
DNV KEMA is now DNV GL



R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv12, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp13, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr13, sBr15, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop5
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl16
13: Time sync	sTm1, sTm2, sTmN1	sTm3, sTmN2
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	
15: Service tracking		sTrk1, sTrk2, sTrk7, sTrk8