

No. 10249379-INC 20-3057

Issued to:

Mitsubishi Electric Corporation
1-1-2 Wadasaki-Cho, Hyogo-ku
652-8555 kobe
Japan

For the server product:

MCD-HA(506PNA) Line Protection Relay
IEC 61850 software version: 2.0.1.0
Relay software version: PGLI11 A
Hardware version: 506PNA
S/N: PN0000-12102

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev5 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in MCD-HA, MRD-HA, MBP-H1A, JEPF-EL1645 Rev.1.02", "Model Implementation Conformance Statement for the IEC 61850 Edition 2 interface in MCD-HA, JEPF-EL1622, Rev.1.02" and "Tissues Implementation Conformance Statement (TICS) for the IEC 61850 Edition 2 interface in MCD-HA, MRD-HA, MBP-H1A, JEPF-EL1646 Rev.1.02" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Edition 2 server interface in MCD-HA, MRD-HA, JEPF-EL1647 Rev.1.02".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (20/28)	9a GOOSE Publish (11/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (17/18)
4 Setting Group Selection (4/4)	12a Direct Control (5/17)
4+ Setting Group Definition (12/13)	12d Enhanced SBO Control (14/27)
5 Unbuffered Reporting (19/22)	13 Time Synchronization (5/7)
6 Buffered Reporting (27/32)	14 File Transfer (5/8)

This certificate includes a summary of the test results as carried out at DNV GL in the Netherlands with UniGrid SA Simulator 1.7.1 with test suite 1.1.0 and UniCA 61850 Analyzer 6.40.01. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10249379-INC 20-3056 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Mitsubishi Electric. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, November 23, 2020



N.A. Heijker
Business Leader
Interoperability of Smart Power Systems

Issued by:



DNV-GL
DNV KEMA is now DNV GL



R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv8, sSrv9, sSrv10, sSrvN1f
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr15
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3, sTmN2
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- MCD-HA(502PNA) Line Protection Relay
- MBP-H1A(502PTA) Bus Bar Protection Relay
- MRD-HA(744PSA) Transformer Protection Relay