



IEC 61850 Certificate Level B¹

No. 50745.6SR3.801

Issued to:
GE Power Management S.L
Av. Pinoa 10
48170 Zamudio Spain



For the server product:
3 series SR350 Feeder Protection System
Main Firmware Rev 2.30
Comm Firmware Rev 2.30
Comm HW Rev A

The server product has not been shown to be non-conforming to:
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.03, the product's protocol, model and technical issue implementation conformance statements: "3 Series PICS ServerEd1 V2.30", "3 Series MICS ServerEd1 V2.30", "3 Series TICS ServerEd1 V2.30" and extra information for testing "3 Series PIXIT ServerEd1 V2.30".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of tests cases):

| | | | |
|----|------------------------------|-----|---------------------------------|
| 1 | Basic Exchange (21/24) | 12a | Direct Control (4/ 11) |
| 2 | Data Sets (3/6) | 12b | SBO Control (6/ 14) |
| 5 | Unbuffered Reporting (18/18) | 12c | Enhanced Direct Control (6/ 13) |
| 6 | Buffered Reporting (25/27) | 12d | Enhanced SBO Control (10/ 19) |
| 9a | GOOSE Publish (10/12) | 13 | Time Synchronization (4/5) |
| 9b | GOOSE Subscribe (11/11) | | |

This certificate includes a summary of the test results as carried out at Grid Automation Laboratories in UK Grid Solutions Limited in Stafford, United Kingdom with UniCA 61850 client simulator version 4.29.03 with test suite version 3.29.00 and the UniCA 61850 Analyzer version 5.28. This document has been issued for information purposes only, and the original paper copy of the Grid Automation Laboratories report: No. 50745.6SR3.301 will prevail.

The tests have been carried out on one single specimen of the product as referred above and submitted to Grid Automation Laboratories by GE Power Management S.L. The manufacturer's production process has not been assessed. This certificate does not imply Grid Automation Laboratories at UK Grid Solutions Limited has approved any product other than the specimen tested.

Stafford, 08-02-2017

Allen Millard
Grid Automation Laboratories Manager

Hua Qin
Grid Automation Laboratories
IED Communication Test Engineer

¹ Level B - Test lab at least following ISO 9001



IEC 61850 Certificate Level B

No. 50745.6SR3.801

Page 2/2

Applicable Test Procedures from the UCA International Users Group Sever Device Test Procedures version 3.03.

| Conformance Block | Mandatory | Conditional |
|------------------------------|--|---|
| 1: Basic Exchange | Ass1, Ass2, Ass3, AssN2, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4 | AssN3 Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3 |
| 2: Data Sets | Dset1, Dset10a, DsetN1ae | |
| 5: Unbuffered Reporting | Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2, RpN3, RpN4, RpN8 | Rp5, Rp6, Rp7, Rp8, Rp10, Rp11, Rp12, RpN5 |
| 6: Buffered Reporting | Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28 BrN1, BrN2, BrN3, BrN4, BrN5, BrN8 | Br5, Br6, Br7, Br8, Br10, Br11, Br12 |
| 9a: GOOSE Publish | Gop2, Gop3, Gop4, Gop9, Gop10a | Gop1, Gop6, Gop7, Gop10b, GopN1 |
| 9b: GOOSE Subscribe | Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6 | Gos1b, Gos4 |
| 12a: Direct Control | CtlN3, DOns1 | CtlN11, DOns3 |
| 12b: SBO Control | CtlN1, CtlN2, CtlN3, CtlN4, SBOns2 | CtlN11 |
| 12c: Enhanced Direct Control | CtlN3, DOes2, DOes5 | CtlN6, CtlN8, CtlN11 |
| 12d: Enhanced SBO Control | CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3 | CtlN6, CtlN11, |
| 13: Time sync | Tm1, Tm2 | Tm3, TmN1 |

All configuration file and data model tests have been successfully performed for the product variants using the same hardware and software version: SR345, SR339.

