

No. 10111820-INC 18-2847

Issued to:

ZIV Aplicaciones y Tecnología SL
Parque Tecnológico de Bizkaia, 210
48170 Zamudio, Vizcaya
Spain

For the server product:

IRL-F
Directional Overcurrent Protection with Sensitive
Ground
Software version: 0.9.0
Hardware version: IRL-F-1BCAAABBA1B
S/N:145004

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in IRL-F from ZIV Aplicaciones y Tecnología 09/07/2018, V0.0", "Model Implementation Conformance Statement for the IEC 61850 interface in IRL 26/07/2018, V0.0, IRL-F-1xxAAABxx1x-2000-0210" and "Tissues Implementation Conformance Statement for the IEC 61850 Ed2 interface in IRL-F 09/07/2018, V0.0" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in IRL-F from ZIV Aplicaciones y Tecnología 09/07/2018, V0.0".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (25/26)	9b GOOSE Subscribe (12/14)
2 Data Sets (4/7)	12a Direct Control (10/18)
4 Setting Group Selection (4/4)	12b SBO Control (16/27)
4+ Setting Group Definition (12/13)	12c Enhanced Direct Control (12/20)
5 Unbuffered Reporting (19/21)	12d Enhanced SBO Control (17/28)
6 Buffered Reporting (28/30)	13 Time Synchronization (6/7)
9a GOOSE Publish (11/13)	14 File Transfer (6/8)

This certificate includes a summary of the test results as carried out at ZIV in Spain with UniGrid SA Simulator 1.4.431 with test suite 1.0.12 and UniCA 61850 Analyzer 5.34.01. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10111820-INC 18-2846 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by ZIV. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, September 3, 2018


S.J.T. Mulder
Business Leader
Interoperability of Smart Power Systems

Issued by:

DNV-GL
DNV KEMA is now DNV GL


R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrv13, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr13, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop6, sGop7, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl2, sCtl7, sCtl13, sCtl15, sCtl16, sCtl17
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOs1, sSBOs2, sSBOs6	sCtl2, sCtl6, sCtl7, sCtl15, sCtl16, sCtl17, sCtl27
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl2, sCtl7, sCtl13, sCtl14, sCtl15, sCtl16, sCtl17, sCtl26
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl2, sCtl6, sCtl7, sCtl15, sCtl16, sCtl17, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3, sTm4, sTm5
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt3