

## IEC 61850 Certificate Level A1

No. 2019PUCA005

Issued to:

XI'AN GENTLE MELLOW TECHNOLOGY CO.,LTD. NO.2, West Side Rd of West 3rd Ring Rd,Hi-tech Industries Development Zone,Xi'an,China

For the product:

FCU-320 SVG Measurement and Control Device Software Version: GMT-SVG V1.0

Issued by: **KEOP**开誓

The server product has not been shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations.

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.2, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for FCU-320 SVG Measurement and Control Device", "Modeling Implementation Conformance Statement(MICS) for FCU-320 SVG Measurement and Control Device", "IEC 61850 Tissues Conformance Statement (TICS) for FCU-320 SVG Measurement and Control Device", and the extra information for testing: "Protocol implementation extra information (PIXIT) of the IEC 61850 communication interface in FCU-320 SVG Measurement and Control Device".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

- 1 Basic Exchange (22/24)
- 2 Data Sets (3/6)
- 4 Setting Group Selection (3/3)
- 4+ Setting Group Definition (7/7)
- 5 Unbuffered Reporting (17/18)

- 6 Buffered Reporting (24/27)
- 12a Direct control (3/11)
- 12d Enhanced SBO Control (10/19)
- 13 Time sync (3/5)

This Certificate includes a summary of the test results as carried out at the KETOP Lab's offices in Xuchang, China with UniCAsim 61850 Client Version 4.29.03 with test suite Version 3.31.00 and UniCA 61850 analyzer Version 5.31.00. This document has been issued for information purposes only, and the original paper copy of the KETOP Lab report: No. JW191974 will prevail.

The test have been carried out on one single specimen of the product as referred above and submitted to KETOP Lab by XI'AN GENTLE MELLOW TECHNOLOGY CO.,LTD. The manufacturer's production process has not been assessed. This certificate does not imply that KETOP Lab has approved any product other than the specimen tested.

Xuchang, Nov 20th, 2019

松春

He Chun
Director of PRTC Department

刘德森

Liu Desen Test Engineer

<sup>1</sup> Level A - Independent Test lab with ISO 17025 Quality System

Page 1 of 2

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

China KETOP Lab (Xuchang KETOP Testing Research Institute Co.,Ltd)
National Center For Quality Supervision & Testing of Relay Protection and Automation Equipment
Intersection between Weiwu Avenue and Shangde Road, XuChang, Henan, P.R. China, P. C. 461000

T +86 374 3212841 F +86 374 3212775 www.ketop.cn



Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2	AssN3, Srv6, Srv7, Srv8, Srv9,
	AssN4, AssN5	Srv10, SrvN1e, SrvN1f, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5,	
	SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, Sg3, SgN1a	
4+: Setting Group Definition	Sg2, Sg4	
	SgN1b, SgN2, SgN3, SgN4, SgN5	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9	Rp5,Rp6,Rp7,Rp8, Rp11, Rp12,
	RpN1, RpN2, RpN3, RpN4, RpN8	RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br20, Br21,	Br5,Br6,Br7,Br8, Br11, Br12
	Br22, Br25, Br26, Br27, Br28	
	BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	
12a: Direct control	CtlN3, DOns1	DOns3
12d: Enhanced SBO control	CtlN1, CtlN2, CtlN3, CtlN4, CtlN9	Ctl3,CtlN6
	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2	TmN1