



## IEC 61850 Certificate Level A<sup>1</sup>

Issued to:

Prolan Power Zrt Szentendrei út 1-3 2011 Budakalász Hungary

## For the client system:

ProField-HE Substation Automation Gateway Software image: IMG 2.1.0 IEC 61850 version: SAG 4.1.0 S/N: 110009/2021

The client system has not been shown to be non-conforming to:

## IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.2 with client system's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 Client interface in ProField-HE, date 2021-10-19", "Model Implementation Conformance Statement (MICS) for the IEC 61850 Edition 2 Client interface in ProField-HE, date 2021-10-20" and "TISSUEs Implementation Conformance Statement (TICS) for the IEC 61850 Edition 2 client interface in ProField-HE, date 2021-09-02" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Client interface in ProField-HE, dated 2021-10-22".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 2 5 6	Basic Exchange (16/24) Data Sets (6/10) Unbuffered Reporting (20/24) Buffered Reporting (24/28)	12c 12d 13	Direct Control (6/9) SBO Control (8/11) Enhanced Direct Control (6/9) Enhanced SBO Control (8/11) Time Synchronization (4/4)
		13 14 15	Time Synchronization (4/4) File Transfer (6/8) Service Tracking (7/17)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniCA 61850 IED Simulator version 6.1.31 and UniCA 61850 Analyzer 6.40.01. This document has been issued for information purposes only, and the archived DNV verification report No. 10298176-INC 21-3447 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Prolan Power. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

**Issued by:** 

Arnhem, October 25, 2021

N.A. Heijker

Business Leader Interoperability of Smart Power Systems

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

DN/

Tel . +31 26 356 9111 Fax. +31 26 351 3683 www.dnv.com contact@dnv.com

R. Schimme

Verification Manager





## IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.2

Conformance Block		Mandatory	Conditional	
1:	Basic Exchange	cAss1, cAss2, cAss3, cAssN1, cAssN4, cAssN5, cAssN6	cAssN7, cSrv4, cSrv5, cSrv7, cSrv10, cSrvN1, cSrvN3, cSrvN5, cSrvN6	
2:	Data Sets		cDs1, cDs2, cDs5, cDs6, cDsN1a, cDsN1b	
5:	Unbuffered Reporting	cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRp11, cRp13a, cRp14, cRp15, cRp19, cRpN2, cRpN5, cRpN6	cRp2, cRp6, cRp7, cRp16, cRp18, cRpN1	
6:	Buffered Reporting	cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr13a, cBr14, cBr15, cBr19, cBr30, cBr31, cBrN2, cBrN5, cBrN6	cBr2, cBr6, cBr7, cBr16, cBr18, cBr32, cBr33, cBrN1	
12a:	: Direct Control	cCtl4, cCtl5, cDOns1, cDOns2	cCtl1, cCtl2	
12b	: SBO Control	cCtl4, cCtl5, cSBOns1, cSBOns2, cSBOns3	cCtl1, cCtl2, cSBOns4	
12c:	Enhanced Direct Control	cCtl4, cCtl5, cDOes1, cDOes2	cCtl1, cCtl2	
12d:	Enhanced SBO Control	cCtl4, cCtl5, cSBOes1, cSBOes2, cSBOes3	cCtl1, cCtl2, cSBOes4	
13:	Time sync	cTm1, cTmN1	cTm2, cTmN2	
14:	File transfer	cFt1, cFt3, cFtN1	cFt4, cFt5, cFtN3	
15:	Service Tracking		cTrk1, cTrk2, cTrk4, cTrk7, cTrk8, cTrk9, cTrk11	