

# CENTRAL POWER RESEARCH INSTITUTE

Prof. Sir C V Raman Road, PO Box 8066, Sadashivanagar PO,  
BANGALORE 560 080. INDIA



**UCA**  
International  
Users Group

## IEC 61850 Certificate Level A<sup>1</sup>



No.: CPRI BLRMUADSASL22TC0002

**Issued to:**

M/s. GE T&D INDIA LIMITED  
19/1, G.S.T. ROAD, PALLAVARAM,  
CHENNAI – 600043,  
TAMIL NADU, INDIA

**For the server product:**

Transformer Protection System  
Type: MULTILIN T60  
Model No.: T60W22HKHF8NH6DM8LP4LU8LW6U  
Serial No.: ABHC19001355  
Hardware Version: T60  
Software Version: UR Family Version 8.05

**Issued by: CENTRAL POWER RESEARCH INSTITUTE, India**

**The server product has not been shown to be non-conforming to:  
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1  
Communication networks and systems for power utility automation**

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.3 with product's protocol, model and technical issue implementation conformance statements: "PICS UR Family version 8.05; dated: 18<sup>th</sup> September 2020", "MICS UR Family version 8.05; dated: 18<sup>th</sup> September 2020", "TICS UR Family version 8.05; dated: 18<sup>th</sup> September 2020" and product's extra information for testing: "PIXIT UR Family version 8.05; dated: 18<sup>th</sup> September 2020".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

1 Basic Exchange (25/26)	12a Direct Control (10/19)
2 Data Sets (4/7)	12b SBO Control (17/28)
4 Setting Group Selection (4/4)	12c Enhanced Direct Control (12/21)
5 Unbuffered Reporting (19/23)	12d Enhanced SBO Control (18/29)
6 Buffered Reporting (27/33)	13 Time Synchronization (5/7)
9a GOOSE Publish (12/13)	14 File Transfer (6/8)
9b GOOSE Subscribe (19/20)	

This Certificate includes a summary of the test results as carried out at Central Power Research Institute (CPRI), Bangalore in India with Client Simulator UniGrid SA Simulator version 1.8.0 with test suit version Ed2\_Server\_TP\_2.0\_20211006.3 and UniCA 61850 analyzer version 6.41.00.0. This document has been issued for information purposes only, and the original paper copy of the CPRI report No.: CPRI BLRMUADSASL22TC0002; dated 28 April, 2022 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to CPRI by M/s. GE T&D INDIA LIMITED, 19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI – 600043, TAMIL NADU, INDIA. The manufacturer's production process has not been assessed. This certificate does not imply that CPRI has certified or approved any product other than the specimen tested.

Bangalore; 28 April, 2022

(V Shivakumar)  
Joint Director



(Pradish M)  
Test Engineer

<sup>1</sup> Level A – Independent Test lab with certified ISO/IEC 17025 Quality System.  
UCA International Users Group, P.O. Box 315, Shell Knob, MO 65747, USA



No.: CPRIBLRMUADSASL22TC0002

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.3

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, sSrvN4	sAssN6, sSrv6, sSrv9, sSrv10, sSrv12, sSrv13, sSrvN1e, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr15
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop5, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos6b
12a Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl2, sCtl7, sCtl13, sCtl15, sCtl16, sCtl18
12b SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl2, sCtl4, sCtl6, sCtl7, sCtl15, sCtl16, sCtl18, sCtl27
12c Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl2, sCtl7, sCtl13, sCtl14, sCtl15, sCtl16, sCtl18, sCtl26
12d Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl2, sCtl4, sCtl6, sCtl7, sCtl15, sCtl16, sCtl18, sCtl26
13 Time sync	sTm1, sTm2, sTmN1	sTm3, sTm5
14 File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt3



(V Shivakumar)  
Joint Director



(Pradish M)  
Test Engineer