

IEC 61850 Certificate Level A¹

No. 23TC200185

Issued to:
Kyongbo Electric Co, Ltd.
5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul,
Republic of Korea

For the server product:
Protection IED (K-IED ABK100)
MCU version: 2.00
DSP version: 1.00
COMM version: 2.00

Issued by:
Korea Electrotechnology Research Institute
111, Hanggaul-ro, Sangrok-gu, Ansan-si, Gyeonggi-do, 15588, Republic of Korea

The server product has not been shown to be non-conforming to:
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in <<K-IED ABK100_PICS v.1.0>>", "Model Implementation Conformance Statement for the IEC 61850 interface in <<K-IED ABK100_MICS v.1.0>>", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in <<K-IED ABK100_TICS v.1.0>>" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing for the IEC 61850 interface in <<K-IED ABK100_PIXIT v.1.0>>".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

1	Basic Exchange (17/26)	9a	GOOSE Publish (7/13)
2	Data Sets (3/7)	9b	GOOSE Subscribe (20/20)
2+	Data Set Definition (20/24)	12a	Direct Control (7/19)
4	Setting Group Selection (3/4)	12d	Enhanced SBO Control (15/29)
5	Unbuffered Reporting (22/23)	13	Time Synchronization (4/7)
6	Buffered Reporting (32/33)	14	File Transfer (5/8)
		15	Service Tracking (6/17)

This certificate includes a summary of the test results as carried out at KERI in Republic of Korea with UniGrid v.2.0.1 with test suite Ed2_Server_TP2.0.5_v1.1.1+755 and UniCA Analyzer v.5.40.01. This document has been issued for information purposes only, and the original paper copy of the KERI report: No. 23TC200185 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KERI by Kyongbo Electric Co., Ltd. The manufacturer's production process has not been assessed. This certificate does not imply that KERI has certified or approved any product other than the specimen tested.

Republic of Korea, March 28, 2023



J. H. Kim
Technical Manager
Power Apparatus Testing and Evaluation Division



S. J. Rim
Principal Engineer

¹ Level A - Independent Test lab with certified ISO/IEC 17025 Quality System
UCA Users Group, P.O. Box 315, Shell Knob, MO 65747, USA



Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test
Procedures version 2.0.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, sSrvN4	sSrv12
2: Data Sets	sDs1, sDs10a, sDsN1ae	
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	
4: Setting Group Selection	sSg1, sSg3, sSgN1	
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr15, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos6b, sGos13
12a Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl15, sCtl16
12d Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl2, sCtl4, sCtl7, sCtl15, sCtl16
13 Time sync	sTm1, sTm2, sTmN1	sTmN2
14 File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	
15 Service tracking		sTrk1, sTrk2, sTrk8, sTrk9, sTrk10, sTrk11

