



# IEC 61850 Certificate Level A<sup>1</sup>

No. 2023PUCA000007

Issued to:  
BEIJING SIFANG AUTOMATION CO., LTD.  
BEIJING SIFANG ENGINEERING CO., LTD.  
Number9, Shangdi 4th Street, Haidian District, Beijing,  
P.R.C.100085 Province, China

For the product:  
CSC-285 Multifunction Voltage Protection LED  
Software version: V1.0

Issued by: **KETOP** 开普

**The server product has not been shown to be non-conforming to:**  
**IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
**Communication networks and systems for power utility automation**

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for CSC-285 Multifunction Voltage Protection LED", "Model Implementation Conformance Statement (MICS) for CSC-285 Multifunction Voltage Protection LED", "TISSUES Implementation Conformance Statement (TICS) for CSC-285 Multifunction Voltage Protection LED" and product's extra information for testing: "Protocol Implementation extra Information for Testing (PIXIT) for CSC-285 Multifunction Voltage Protection LED".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (22/26)	5 Unbuffered Reporting (20/23)
2 Data Sets (3/7)	6 Buffered Reporting (28./33)
3 Substitution (3/3)	12d Enhanced SBO Control (12/28)
4 Setting Group Selection (4/4)	13 Time Synchronization (3/7)
4+ Setting Group Definition (12/13)	14 File Transfer (5/8)

This certificate includes a summary of the test results as carried out at Xuchang KETOP Testing Research Institute Co.,Ltd in Xuchang, China with UniGrid Substation Automation V2.1.0 with test suite V2.0.6 and UniCA 61850 Analyzer V6.41.0.0, UniCASim SCL checker v3.37.01, This document has been issued for information purposes only, and the original paper copy of the KETOP Lab report: No. JW234066E-Protocol will prevail.

The test have been carried out on one single specimen of the product as referred above and submitted to KETOP Lab by Hangzhou Deruida Electric Co., Ltd. The manufacturer's production process has not been assessed. This certificate does not imply that KETOP Lab has approved any product other than the specimen tested.

Xuchang, Dec 08<sup>th</sup>, 2023

He Chun  
Director of PRTC Department

Liu Desen  
Test Engineer

<sup>1</sup> Level A - Independent Test lab with ISO 17025 Quality System

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

**China KETOP Lab ( Xuchang KETOP Testing Research Institute Co.,Ltd )**  
**National Quality Inspection & Testing Center For Relay Protection And Automation Equipment**

No. 17 Shangde Road , Xuchang, Henan Province, China P.C.461000  
T +86 374 3212841 F +86 374 3212775 www.ketop.cn



Applicable Test Procedures from the UCA International Users Group Conformance Test Procedures for Server Devices with IEC 61850-8-1 Edition 2 Interface Revision 2.0.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5 sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6 sSrv6, sSrv9, sSrv10, sSrvN1e, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12 sSgN2, sSgN3, sSgN4, sSgN5	sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16 sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp11, sRp12, sRp17, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29 sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr11, sBr12, sBr17
12d: Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl15, sCtl16
13 Time sync	sTm1, sTm2, sTmN1	
14 File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	

This certificate is issued in accordance with the laboratory accreditation requirements of the UCA International Users Group. This certificate shall only be reproduced in full and with the express permission of KETOP lab.

**China KETOP Lab ( Xuchang KETOP Testing Research Institute Co.,Ltd )**  
**National Quality Inspection & Testing Center For Relay Protection And Automation Equipment**

No. 17 Shangde Road , Xuchang, Henan Province, China P.C.461000  
 T +86 374 3212841 F +86 374 3212775 www.ketop.cn