

## IEC 61850 Certificate Level A<sup>1</sup>

**Issued to:**

Hitachi Energy Sweden AB  
GA Products  
SE-721 59 Västerås  
Sweden

**For the server product:**

PWC600 Point-on-Wave Controller IED  
Product version: 3.0.1  
Software version: 0.6.17.284  
S/N: T2344095

The server product has not been shown to be non-conforming to:

### IEC 61850 Edition 2 with Amendment 1 Parts 6, 7-1, 7-2, 7-3, 7-4, 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 and the UCA International Users Group Edition 2 with Amendment 1 Server Test Procedures version 1.2 with product's protocol, model and tissues implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 Edition 2 and 2.1 interface in Relion Switchsync® PWC600 Version 3.0.1, 1MRG518080, Rev. A", "Model Implementation Conformance statement for the IEC 61850 Ed2.1 in Relion Switchsync® PWC600, version 3.0.1, 1MRG043436, Rev. A", "TISSUES Implementation Conformance Statement (TICS) for the IEC 61850 Edition 2.1 server interface in Relion Switchsync® PWC600 Version 3.0.1, 1MRG518082, Rev. A", and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Edition 2 and 2.1 server interface in Relion Switchsync® PWC600 Version 3.0.1, 1MRG518081, Rev. A".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1a Basic Exchange (22/29)	9a GOOSE publish (10/13)
2 Data Sets (4/7)	9b GOOSE subscribe (27/27)
3 Substitution (3/3)	13a Time Synchronization with SNTP (8/8)
4 Setting Group Selection (5/5)	14 File Transfer (7/8)
5 Unbuffered Reporting (23/26)	15 Service Tracking (9/17)
6 Buffered Reporting (33/36)	

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 2.2.1 with test suite 20240314 and UniCA 61850 Analyzer 6.41.00. This document has been issued for information purposes only, and the archived DNV verification report No. 10452508-DSO 24-4137 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Hitachi Energy Sweden AB. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, April 24, 2024



**R. Botezatu**  
Test Engineer

Issued by:




**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System  
UCA International Users Group P.O. Box 315, Shell Knob, MO 65747 USA

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

## IEC 61850 Certificate Level A

Applicable Server Test Procedures from the UCA International Users Group Edition 2 with Amendment 1 Server Test Procedures version 1.2

Conformance Block	Mandatory	Conditional
1a: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6, sSrv9, sSrv10, sSrv12, sSrv13, sSrv15
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11, sSg13
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRp23, sRpN1, sRpN2, sRpN3, sRpN4, sRpN5, sRpN7, sRpN8, sRpN9	sRp8, sRp10, sRp11, sRp12, sRp13, sRp15
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr23, sBr24, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN7, sBrN8, sBrN9, sBrN10	sBr8, sBr10, sBr11, sBr12, sBr13, sBr15
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGos14, sGos15, sGos20, sGos21, sGos22, sGos23, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6, sGosN7	sGos4, sGos6b, sGos13
13a: Time sync SNTP	sTm1, sTm2, sTm7, sTmN1	sTm3, sTm4, sTm5, sTmN2
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt2c, sFtN1c
15: Service tracking		sTrk1, sTrk2, sTrk4, sTrk7, sTrk8, sTrk9, sTrk10, sTrk11, sTrk17