



IEC 61850 Certificate Level A¹

Page 1/2 No. 23-075850-01-1

Issued to: Songam Syscom CO., Ltd. 32, Donghwagongdan-ro, Munmak-eup, Wonju-si, Gangwon-do, Republic of Korea For the client system: xGrids Transfer SONGAM-MIT Software Version 1.0 HW : HPE ProLiant DL380 Gen10 OS : Ubuntu 22.04.5 LTS S/N : SA-23MIT0001

Issued by: KOREA TESTING LABORATORY

The CLIENT has not been shown to be non-conforming to: IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Client Test Procedures version 1.2 with product's protocol, model and technical issue implementation conformance statements: "MIT_PICS_v.1.0", "MIT_MICS_v.1.0", "MIT_TICS_v.1.0" and product's extra information for testing: "MIT_PIXIT_v.1.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| 1 2 4 5 | Basic Exchange (20/24) Data Sets (8/10) Setting Group Selection (3/3) Unbuffered Reporting (21/24) | 12b 12c 12d 13 | SBO Control (9/11) Enhanced Direct Control (7/9) Enhanced SBO Control (9/11) Time Synchronization (4/4) |
|------------------|---|-------------------------|--|
| 5 6 | Buffered Reporting (25/28) | 13 | File Transfer (6/8) |
| 12a | Direct Control (7/9) | 15 | Service Tracking (5/17) |

This certificate includes a summary of the test results as carried out at Seoul in the Republic of Korea with IEC 61850 Ed2 Virtual Server version 1 with test suite IEC 61850 Ed2 Client Conformance Verifier1.0 and KEPCO ANALYZER 1.0. This document has been issued for information purposes only, and the original paper copy of KTL report: No. TR-23-075850-01-1 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KTL by Songam Syscom CO., Ltd. The manufacturer's production process has not been assessed. This certificate does not imply that KTL has certified or approved any product other than the specimen tested.

Seoul, Feb. 24. 2025

HAM

Ah Han Principal Engineer IT Convergence Technology Center

YoungKwang Yun Assistant Research Engineer IT Convergence Technology Center

1 Level A - Independent Test lab with accredited ISO/IEC 17025 Quality System





Applicable Test Procedures from the UCA International Users Group Edition 2 Client Test Procedures version 1.2

| Conformance Block | Mandatory | Conditional | |
|---------------------------------|--|---|--|
| 1: Basic Exchange | cAss1, cAss2, cAss3, cAssN1, | cAssN7 | |
| | cAssN4, cAssN5 cAssN6 | cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrvN1, cSrvN3, cSrvN4, cSrvN5, cSrvN6 | |
| 2: Data Sets | | cDs1, cDs2, cDs3, cDs5, cDs6, cDsN1a, cDsN1b, cDsN1c | |
| 4: Setting Group Selection | cSg2, cSgN1 | cSg1 | |
| 5: Unbuffered Reporting | cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRp11, cRp13a, cRp14, cRp15, cRp19, cRpN2, cRpN5, cRpN6 | cRp1, cRp2, cRp6, cRp7, cRp16, cRp17, cRpN1 | |
| 6: Buffered Reporting | cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr13a, cBr14, cBr15, cBr19, cBr30, cBr31, cBrN2, cBrN5, cBrN6 | cBr1, cBr2, cBr6, cBr7, cBr16, cBr17, cBr32, cBr33, cBrN1 | |
| 12a: Direct control | cCtl4a, cCtl5a, cDOns1, cDOns2 | cCtl1a, cCtl2a, cCtl3a | |
| 12b: SBO control | cCtl4b, cCtl5b, cSBOns1, cSBOns2, cSBOns3 | cCtl1b, cCtl2b, cCtl3b, cSBOns4 | |
| 12c: Enhanced Direct Control | cCtl4c, cCtl5c, cDOes1, cDOes2 | cCtl1c, cCtl2c, cCtl3c | |
| 12d: Enhanced SBO control | cCtl4d, cCtl5d, cSBOes1, cSBOes2, cSBOes3 | cCtl1d, cCtl2d, cCtl3d, cSBOes4 | |
| 13: Time sync | cTm1, cTmN1 | cTm2, cT <mark>mN2</mark> | |
| 14: File transfer | cFt1, cFt3, cFtN1 | cFt2, cFt5, cFtN2 | |
| 15: Service Tracking | | cTrk1, cTrk2, cTrk7, cTrk8, cTrk9 | |