

IEC 61850 Certificate Level A¹

Issued to:

HITACHI Energy Sweden AB
GA Products
S-721 59 Västerås
Sweden

For the server product:

REC670 Bay Control
Product version: 2.2.7
Software version: 2.2.22.1
S/N: T1826147

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 Edition 2 & 2.1 interface in Relion 670 series version 2.2.7, Date 2025-03-12", "Relion 670 series version 2.2.7 Ed 2 MICS, Template version 1.2" and "Relion 670 series version 2.2.7 Ed2 - TICS, Date 2025-03-12" and the extra information for testing: "Relion 670 series version 2.2.7 Ed2.1 - PIXIT, Date 2025-03-12".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (25/26)	9a GOOSE Publish (10/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (21/21)
3 Substitution (3/3)	12a Direct Control (11/18)
4 Setting Group Selection (4/4)	12c Enhanced Direct Control (13/20)
4+ Setting Group Definition (13/13)	12d Enhanced SBO Control (19/28)
5 Unbuffered Reporting (20/23)	13 Time Synchronization (7/7)
6 Buffered Reporting (30/33)	14 File Transfer (7/8)
	15 Service Tracking (11/17)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 3.1.1 with test suite 20250213 and UniCA 61850 Analyzer 6.45. This document has been issued for information purposes only, and the archived DNV verification report No. 10546566-DSO 25-2418 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by HITACHI Energy Sweden AB. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, March 6, 2025



P. Pourebrahim
Test Engineer

Issued by:




R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

UCA International Users Group P.O. Box 315, Shell Knob, MO 65747 USA

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv9, sSrv10, sSrv11, sSrv12, sSrv13, sSrvN1e, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp13, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr13, sBr15, sBr23, sBr24
9a: GOOSE Publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGopN1, sGopN2
9b: GOOSE Subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGos23, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos6b, sGos13
12a: Direct Control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl13, sCtl15, sCtl16, sCtl17, sCtl18, sCtl28
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl13, sCtl14, sCtl15, sCtl16, sCtl17, sCtl18, sCtl26, sCtl28
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl7, sCtl15, sCtl16, sCtl17, sCtl18, sCtl26, sCtl28
13: Time Sync	sTm1, sTm2, sTmN1	sTm3, sTm4, sTm5, sTmN2
14: File Transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt2c, sFtN1c
15: Service Tracking		sTrk1, sTrk2, sTrk4, sTrk7, sTrk8, sTrk9, sTrk10, sTrk11, sTrk13, sTrk14, sTrk17

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- REB670 Busbar Protection
- RET670 Transmission Transformer Protection
- RED670 Transmission Line Differential Protection
- RER670 Railway Application
- RES670 Phasor Measurement Unit
- REG670 Generator Protection
- REL670 Transmission Line Distance Protection