



International Usersgroup

IEC 61850 Certificate Level A¹

No. 74104098-MOC/INC 13-1310

Issued to:
Yousung Instrument & Electric Co.
#7-13, Songdo-dong, Yeonsu-gu
Incheon
Republic of Korea

For the client system:
YSSA-Gateway
Software: 1.0
Hardware: Advantech UNO-4683C with
Windows 7

Issued by:



The client system has not shown to be non-conforming to:
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 and UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL² version 1.2 with client system's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for YSSA-Gateway with version 1.0", "Model Implementation Conformance Statement for the IEC 61850 interface in YSSA-Gateway with version 1.0", "IEC 61850 Tissues Conformance Statement (TICS) for YSSA-Gateway with version 1.0" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) of the IEC 61850 interface in the client system YSSA-Gateway with version 1.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):


1	Basic Exchange (22/22)	12a	Direct Control (6/7)
2	Data Sets (5/9)	12b	SBO Control (8/9)
2+	Data Set Definition (4/4)	12c	Enhanced Direct Control (6/7)
4	Setting Group Selection (4/4)	12d	Enhanced SBO Control (8/9)
4+	Setting Group Definition (2/2)	13	Time Synchronization (4/4)
5	Unbuffered Reporting (16/18)	14	File Transfer (6/8)
6	Buffered Reporting (20/22)		

This certificate includes a summary of the test results as carried out at KEMA in the Netherlands with UniCA Multi IED Simulator version 3.26.1 and UniCA 61850 Analyzer version 4.25.00 This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74104098-MOC/INC 13-1311 will prevail.

The test has been carried out on one single specimen of the client system as referred above and submitted to KEMA by Yousung Instrument & Electric Co. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, March 25, 2013


M. Adriaansen
Director Intelligent Networks & Communication


R. Schimmel
Certification Manager

¹ Level A - Independent test lab with certified ISO 9001 quality system

² TPCL - Test Procedure Change List

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL version 1.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	cAss1, cAss2, cAss3, cAss4, cAssN1, cAssN4, cAssN5, cAssN6	cAssN7 cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrvN1, cSrvN2, cSrvN3, cSrvN4, cSrvN5, cSrvN6
2: Data Sets		cDs1, cDs2, cDs5, cDsN1a, cDsN1b
2+: Data Set Definition	cDs6, cDsN4	cDs7, cDsN5
4: Setting Group Selection	cSg2, cSgN1	cSg1, cSg3
4+: Setting Group Definition	cSg3, cSg4	
5: Unbuffered Reporting	cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRpN2, cRpN3, cRpN7, cRpN8	cRp1, cRp2, cRp6, cRp7, cRpN1, cRpN4
6: Buffered Reporting	cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr12, cBrN2, cBrN3, cBrN7, cBrN8, cBrN9	cBr1, cBr2, cBr6, cBr7, cBr13, cBrN1, cBrN4
12a: Direct control	cCtl4, cCtlN1 cDOs1, cDOs2	cCtl1, cCtl2
12b: SBO control	cCtl4, cCtlN1 cSBOs1, cSBOs2, cSBOs3	cCtl1, cCtl2 cSBOs4
12c: Enhanced Direct Control	cCtl4, cCtlN1 cDOes1, cDOes2	cCtl1, cCtl2
12d: Enhanced SBO control	cCtl4, cCtlN1, cSBOes1, cSBOes2, cSBOes3	cCtl1, cCtl2 cSBOes4
13: Time sync	cTm1	cTm2, cTmN1, cTmN2
14: File transfer	cFt1, cFt2, cFt3, cFtN1, cFtN2	cFt5