

IEC 61850 Certificate Level A¹

Page 1/2

Issued to: TOSHIBA Corporation Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-Shi, Tokyo, 183-8511 Japan No. 30720466-Consulting 07-1603

For the product: GBU100 Bay Control Unit Software Version LBXP-S1-A Communication Firmware GPM850-02-A



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IEC61850 ACSI conformance statement (PICS) 6F2M0350 Rev. 2", "IEC61850 Model Implementation Conformance Statement (MICS) GBU100 6F2M0349 Rev. 1", "IEC61850 Tissues Conformance Statement (TICS) of the IEC 61850 communication interface in GBU100 6F2M0352", and extra information for testing (PIXIT) "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 communication interface in GBU100 6F2M0351 Rev. 2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v1.1):

This Certificate includes a summary of the test results as carried out at Toshiba Corporation in Japan with UniCAsim 61850 version 2.15.01 with test suite 3.16.02 and UniCA 61850 analyzer 4.15.00 and UniCAsim GOOSE v2.14.02 with test suite 2.12.05. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30720466-Consulting 07-1602 will prevail.

The test have been carried out on one single specimen of the products as referred above and submitted to KEMA by Toshiba. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, August 8, 2007

S.J.L.M. Janssen Managing Director KEMA Consulting

Mul

E.F. Melenhorst Senior Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.

KEMA Nederland B.V. Utrechtseweg 310, 6812 AR Arnhem P.O.Box 9035, 6800 ET Arnhem The Netherlands T +31 26 356 61 42 F +31 26 351 54 56 sales@kema.com www.kema.com



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

	-	
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4,	Srv6, Srv7, Srv8, SrvN1e, SrvN3
, C	AssN5, Srv1, Srv2, Srv3, Srv4, Srv5,	
	SrvN1abcd, SrvN4	
2: Data Sets	Dset1, DsetN1ae	
4: Setting Group Selection	Sg1, SgN1	
U U U		
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, BrN1,	Br5, BrN6
	BrN2, BrN3, BrN4, BrN5	
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2, GosN3,	
	GosN4, GosN5, GosN6	
12d Enhanced SBO	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9,	Ctl2, Ctl7
	SBOes1, SBOes2, SBOes3	,
13 Time sync	Tm1, Tm2, TmN1	
14 File transfer	Ft1, Ft2ab, FtN1ab	

Page 2/2