



IEC 61850 Certificate Level A¹

Page 1/2

Issued to:
KEPCO KDN Co., Ltd.
1355 Seocho 2 Dong, Seocho Gu
Seoul, 137-862
South Korea

No. 30107072-Consulting 10-2515

For the product:
Kipro-F
Version 1.0
Feeder Protection IED with protection,
monitoring, control, and interlocking

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IEC 61850_PICS_Kipro-F_20101116", "IEC 61850_MICS_Kipro-F_20101116", "IEC 61850_TICS_Kipro-F_20101116" and product's extra information for testing: "IEC 61850_PIXIT_Kipro-F_20101116".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):


1 Basic Exchange (20/24)	9a GOOSE Publish (7/12)
2 Data Sets (3/6)	9b GOOSE Subscribe (9/10)
2+ Data Set Definition (23/29)	12a Direct Control (7/11)
5 Unbuffered Reporting (15/18)	12d Enhanced SBO Control (12/19)
6 Buffered Reporting (17/20)	13 Time Synchronization (3/4)
	14 File Transfer (4/7)

This Certificate includes a summary of the test results as carried out at KEPRI in Republic of Korea with UniCasim 61850 version 3.21.02 with test suite version 3.21.00 and UniCA 61850 analyzer 4.21.03. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30107072 Consulting 10-2514 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by KEPCO-KDN. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, December 7, 2010


M. A. Jansen
Manager Intelligent Networks and Communication


S.J.T. Mulder
Senior Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14, DsetN15	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10 RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp8, Rp9, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br10, Br11
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop10, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CltN3, CltN8, DOns1, DOns3	Ctl2, Ctl7, CtlN11
12d: Enhanced SBO control	Ctl3, CltN1, CltN2, CltN3, CltN4, CtlN9 SBOes1, SBOes2, SBOes3	Ctl2, Ctl7, CtlN11
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, FtN1ab	Ft4, FtN1c