

IEC 61850 Certificate Level A¹

Page 1/2

Issued to: ALSTOM GRID UK Ltd. St. Leonards Avenue Stafford ST17 4LX United Kingdom No. 74100457-MOC/INC 13-3131

For the server product: MiCOM P40 Agile P643 Transformer Protection Relay Software Version 4H Hardware Version K

Issued by:



The server product has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL² version 1.5, the product's protocol, model and technical issue implementation conformance statements: "MiCOM Px4x PICS, Protocol Implementation Conformance Statement, Px4x/EN PC/A", "MiCOM P643 MICS, Model Implementation Conformance Statement, P643-MC-EN-C52" and "MiCOM P642, P643, P645 TICS, Transformer Protection Relays, P64x/EN TC/B52" and the extra information for testing: "MiCOM P642, P643, P645 PIXIT, Protocol Implementation eXtra Information for Testing for the IEC 61850 Interface in P64x with Software Version 04, P64x/EN/PX/C52".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 2 4 5 6	Basic Exchange (19/24) Data Sets (3/6) Setting Group Selection (2/3) Unbuffered Reporting (16/19) Buffered Reporting (18/21)	12b 12c 12d 13	Direct Control (4/12) SBO Control (6/14) Enhanced Direct Control (4/13) Enhanced SBO Control (9/19) Time Synchronization (3/5)
9a	GOOSE Publish (11/13)	13	File Transfer (6/7)
9b	GOOSE Subscribe (11/11)		

This certificate includes a summary of the test results as carried out at KEMA in Arnhem with UniCA 61850 Client simulator 4.27.04 with test suite 3.27.00 and UniCA 61850 Analyzer 5.27.04. This document has been issued for information purposes only, and the original paper copy of the KEMA report No. 74100457-MOC/INC 13-3130 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by ALSTOM GRID UK Ltd. The manufacturer's production process has not been assessed. This attestation does not imply that KEMA has approved any product other than the specimen tested.

Arnhem, September 16, 2013

M. Adriaensen

Director Intelligent Networks & Communication

¹ Level A - Independent test lab with certified ISO 9001 Quality System ² TPCL - Test procedures change list

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA attestation is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.

Schimmel Certification Manager



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.5

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv6, Srv7, Srv8, SrvN1e, SrvN1f
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, SgN1a	1
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12 RpN1, RpN2, RpN3, RpN4	Rp5, Rp8, Rp9, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10, Br11, BrN6
9a: GOOSE publish		
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct control	CtIN3, CtIN8 DOns1, DOns3	
12b: SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, SBOns2	
12c: Enhanced Direct Control	CtIN3, CtIN8 DOes2, DOes5	
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c

Page 2/2