



IEC 61850 Certificate Level A¹

International Usersgroup

No. 7410551-OPE/INC 14-1208

Issued to:
CYG SUNRI Co., Ltd.
No. 3, Langshan 1st Road,
Hi-tech Park, Nanshan District, Shenzhen
China

For the server product:
PRS-7395 Smart Terminal & Merging Unit
Firmware version: 2.3.2.01
S/N: 3000000001776381



Issued by:

The server product has not shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Device Test Procedures version 2.3 with TPCL² version 1.7.1, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in PRS-7395", "Model Implementation Conformance Statement For the IEC 61850 interface in PRS-7395" and "TISSUES Implementation Conformance Statement for the IEC 61850 interface in PRS-7395" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in PRS-7395".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

9a	GOOSE Publish (7/13)
9b	GOOSE Subscribe (10/11)
13	Time Synchronization (3/5)

This certificate includes a summary of the test results as carried out at DNV KEMA in the Netherlands with UniCA GOOSE Simulator 2.27.1 with test suite 2.27.06 and UniCA 61850 Analyzer 5.27.07. This document has been issued for information purposes only, and the original paper copy of the DNV KEMA test report No. 74105511-OPE/INC 14-1207 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV KEMA by CYG SUNRI Co., Ltd. The manufacturer's production process has not been assessed. This attestation does not imply that DNV KEMA has approved any product other than the specimen tested.

Arnhem, April 9, 2014

M. Adriaansen
Director Intelligent Networks & Communication

R. Schimmel
Certification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list



International
Usersgroup

Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.3 with TPCL version 1.7.1

Conformance Block	Mandatory	Conditional
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop7, Gop9, Gop10a	Gop5
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
13: Time Sync	Tm1, Tm2	TmN1