

# IEC 61850 Certificate Level A<sup>1</sup>

No. 84000022-OPE/INC 15-1680

#### **Issued to:**

Controles S.A. Av. Rivera 3314 11300 Montevideo Uruguay

### For the server product:

RTU194 Bay controller

Software version: RTUQM V4.32

Hardware version: F02-CP02-IA21-IB21-PA03-

PB03-D02

The server product has not been shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 2.3 with TPCL² version 1.7, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in RTU194, Version: 1.7, Date: June 19, 2015", "Model Implementation Conformance Statement for the IEC 61850 interface in RTU194, Version: 1.7, Date: June 19, 2015" and "TISSUES Implementation Conformance Statement for the IEC 61850 interface in RTU194, Version: 1.7, Date: June 19, 2015" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in RTU194, Version: 1.7, Date: June 19, 2015".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

- 1 Basic Exchange (17/24)
- 2 Data Sets (3/6)
- 5 Unbuffered Reporting (15/19)
- 6 Buffered Reporting (17/21)
- 6+ Enhanced buffered reporting (9/12)
- 9a GOOSE Publish (11/13)

- 12a Direct Control (5/12)
- 12b SBO Control (7/14)
- 12c Enhanced Direct Control (6/13)
- 12d Enhanced SBO Control (11/19)
- 13 Time Synchronization (4/5)

This certificate includes a summary of the test results as carried out at Controles in Uruguay with UniCA 61850 Client Simulator 4.29.03 with test suite 3.29.00 and UniCA 61850 Analyzer 5.28.03. This document has been issued for information purposes only, and the original paper copy of the DNV GL report No. 84000022-OPE/INC 15-1690 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Controles. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, June 24, 2015

M. Adriaensen

Head of Department Operational Excellence Issued by:

DNV·GL

DNV KEMA is now DNV GL

R. Schimmel

Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

<sup>2</sup> TPCL - Test procedures change list

Copyright © KEMA Nederland B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.



### IEC 61850 Certificate Level A

No. 84000022-OPE/INC 15-1680

Applicable Test Procedures from the UCAIug Server Device Test Procedures version 2.3 with TPCL 1.7

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5	Srv6, Srv8, SrvN1f
	Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	
2: Data Sets	Dset1, Dset10a, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10, Rp12, RpN1, RpN2, RpN3, RpN4	Rp8, Rp9, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, Br14, BrN1, BrN2, BrN3, BrN4, BrN5	Br10, Br11, BrN6
6+: Enhanced Buffered Reporting	BrE1, BrE2, BrE3, BrE6, BrE7, BrE8, BrE9, BrE10, BrE11	,
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop7, Gop9, Gop10a	Gop1, Gop6, Gop10b, GopN1, GopN2
12a: Direct Control	CtiN3, CtiN8, DOns1	CtlN11, DOns3
12b: SBO Control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, SBOns2	CtIN11
12c: Enhanced Direct Control	CtIN3, CtIN8, DOes2, DOes5	CtIN6, CtIN11
12d: Enhanced SBO Control	Cti3, CtiN1, CtiN2, CtiN3, CtiN4, CtiN9, SBOes1, SBOes2, SBOes3	CtIN6, CtIN11
13: Time Sync	Tm1, Tm2, TmN1	Tm3