

No. 10035067-INC 17-2112

Issued to:

Mitsubishi Electric Corporation
1-1-2 Wadasaki-Cho, Hyogo-ku
652-8555 Kobe
Japan

For the server product:

MFP-H2SB Overcurrent protection relay
IEC 61850 software version: PGKK0308
Relay software version: PGKK48
Hardware version: 652PSA
S/N: 61971100003

The server product has not been shown to be non-conforming to:

IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.03, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for MFP-H2SB, MFP-H1SB – revision 1.02", "Model Implementation Conformance Statement for MFP-H2SB – revision 1.00" and "TISSUES Implementation Conformance Statement (TICS) for MFP-H2SB, revision 1.00" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for MFP-H2SB, MFP-H1SB – revision 1.01".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (16/24)	9a GOOSE Publish (10/12)
2 Data Sets (3/6)	9b GOOSE Subscribe (10/11)
4 Setting Group Selection (3/3)	12a Direct Control (3/11)
5 Unbuffered Reporting (15/18)	13 Time Synchronization (4/5)
6 Buffered Reporting (23/27)	14 File Transfer (4/7)

This certificate includes a summary of the test results as carried out at Mitsubishi Electric Corporation in Japan with UniCA 61850 Client Simulator 4.32.01 with test suite 3.31.00 and UniCA 61850 Analyzer 5.31.00. This document has been issued for information purposes only, and the original paper copy of the DNV GL report No. 10035067-INC 17-2113 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by Mitsubishi Electric Corporation. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, April 20, 2017



P. Cioci
Business Director
Intelligent Networks and Communication

Issued by:



DNV-GL
DNV KEMA is now DNV GL



R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.03

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN3, Srv8, SrvN1f
2: Data Sets	Dset1, Dset10a, DsetN1ae	
4: Setting Group Selection	Sg1, Sg3, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2, RpN3, RpN4, RpN8	Rp5, Rp8, Rp10, Rp11, Rp12
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28, BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	Br5, Br8, Br10, Br11, Br12
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop9, Gop10a	Gop1, Gop6, Gop7, GopN1, GopN2
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b
12a: Direct Control	CtlN3, DOns1	DOns3
13: Time Sync	Tm1, Tm2	Tm3, TmN1
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- MFP-H1SB Feeder protection relay