

IEC 61850 Certificate Level A¹

Page 1/2
No. 17-040368-01

Issued to:
DAEWOONG ELECTRIC
10, Hwanggeum-ro 127beon-gil, Yangchon-eup,
Gimpo-si, Gyeonggi-do, Republic of Korea,
10048

For the server product:
Protocol Converter
DW-SPiN IEC 61850 Server
Version 2.0

Issued by: **Korea Testing Laboratory**

**The server product has not been shown to be non-conforming to:
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations**

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.03, the product's protocol, model and technical issue implementation conformance statements: "DW-SPiN_PICS_V2", "DW-SPiN_MICS_V2", "DW-SPiN_TICS_V2" and the extra information for testing: "DW-SPiN_PIXIT_V2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (22/24)	9a	GOOSE Publish (10/12)
2	Data Sets (3/6)	9b	GOOSE Subscribe (11/11)
2+	Data Set Definition (24/24)	12a	Direct Control (6/11)
4	Setting Group Selection (3/3)	12c	Enhanced Direct Control (8/13)
5	Unbuffered Reporting (18/18)	12d	Enhanced SBO Control (13/19)
6	Buffered Reporting (25/27)	13	Time Synchronization (4/5)
		14	File Transfer (7/7)

This Certificate includes a summary of the test results as carried out at KTL in Republic of Korea with IEC 61850 KTL Testing Tool with test suite IEC 61850 Server Conformance Test V.1.0 and IEC 61850 KTL Trace Manager V.1.0. This document has been issued for information purposes only, and the original paper copy of the KTL report: No. TR-17-040368-01 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KTL by Daewoong Electric. The manufacturer's production process has not been assessed. This certificate does not imply that KTL has approved any product other than the specimen tested.

Seoul, July. 3, 2017

A. Han

Aa Han
Senior Engineer
RF Application Technology Center

T. S. Song

Taeseung Song
Director
RF Application Technology Center

1 Level A - Independent Test lab with certified ISO 17025 Quality System

Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.03

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN3, AssN6 Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14	DsetN15a, DsetN15b
4: Setting Group Selection	Sg1, SgN1a, Sg3	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2, RpN3, RpN4, RpN8	Rp5, Rp6, Rp7, Rp8, Rp10, Rp11, Rp12, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28 BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	Br5, Br6, Br7, Br8, Br10, Br11, Br12
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop9, Gop10a	Gop1, Gop6, Gop7, Gop10b, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct control	CtlN3, DOns1	Ctl2, Ctl7, CtlN11 DOns3
12c: Enhanced Direct control	CtlN3, DOes2, DOes5	Ctl2, Ctl7, CtlN6, CtlN8, CtlN11
12d: Enhanced SBO control	CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	Ctl2, Ctl3, Ctl7, CtlN6, CtlN11
13: Time sync	Tm1, Tm2	TmN1, TmN2
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, Ft3, FtN1c