

IEC 61850 Certificate Level A¹

No. 10166199-INC 19-2787

Issued to: NPP "ALIMP" Bulvar Mira, 19a 603086, NIZHNY NOVGOROD Russian Federation For the server product: PT.9.10.00 Line protection relay Software version: 19.03.1 Hardware version: PT.9.10.00-2-1-UHL4 S/N: 00051

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in PT.9.10.00, version 1.2", "Model Implementation Conformance Statement for the IEC 61850 interface in Line protection relay PT.9.10.00, version 1.2" and "TISSUES Implementation Conformance Statement for the IEC 61850 Ed2 interface in PT.9.10.00, version 1.3" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in PT.9.10.00, version 1.4".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (21/26)	9a	GOOSE Publish (8/13)
2	Data Sets (4/7)	9b	GOOSE Subscribe (12/14)
2+	Data Set Definition (24/24)	12a	Direct Control (4/18)
4	Setting Group Selection (4/4)	13	Time Synchronization (3/7)
5	Unbuffered Reporting (21/21)	14	File Transfer (7/8)
6	Buffered Reporting (28/30)		

This certificate includes a summary of the test results as carried out at R&D CENTER @ FGC UES in the Russian Federation with UniGrid SA Simulator 1.4.452 with test suite 1.0.46 and UniCA 61850 Analyzer 5.34.01. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10166199-INC 19-2786 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by NPP "ALIMP". The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, August 16, 2019

N.A. Heijker Business Leader Interoperability of Smart Power Systems

Issued by:





DNV KEMA is now DNV GL

 $^1\,{\rm Level}\,{\rm A}$ - Independent test lab with certified ISO 9001 Quality System $^2\,{\rm TPCL}$ - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Page 1/2

www.dnvgl.com contact@dnvgl.com



IEC 61850 Certificate Level A

No. 10166199-INC 19-2787

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

Conformance Block		Mandatory	Conditional
1:	Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2:	Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+:	Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
4:	Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5:	Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6:	Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13
9a:	GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop7
9b:	GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a:	Direct control	sCtl5, sCtl10, sDOns1, sDOns2	
13:	Time sync	sTm1, sTm2, sTmN1	
14:	File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt2c, sFtN1c

www.dnvgl.com contact@dnvgl.com