

No. SchneiderElectric_Easergy_P5M30_Ed2

Issued to:

Schneider Electric Industries SAS
35 rue Joseph Monier,
92500 Rueil -Malmaison, France

For the server product:

Easergy P5M30
Motor Protection Device
Software version: V01

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev4 with product's protocol, model and technical issue implementation conformance statements: Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 2 PICS, Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 3 MICS, Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 5 TICS and product's extra information for testing: Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 4 PIXIT.

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (24/28)	9a GOOSE Publish (12/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (16/18)
2+ Data Set Definition (24/24)	12a Direct Control (6/17)
4 Setting Group Selection (4/4)	12b SBO Control (12/26)
4+ Setting Group Definition (13/13)	12c Enhanced Direct Control (8/19)
5 Unbuffered Reports (22/22)	12d Enhanced SBO Control (13/27)
6 Buffered Reports (32/32)	13 Time Synchronization (5/7)
	14 File Transfer (5/8)

This Certificate includes a summary of the test results as carried out at Schneider Electric IEC61850 lab in China with UniGrid SA 1.6.9 and UniCA Analyzer 5.34.01. This document has been issued for information purposes only, and the original paper copy of the Schneider Electric IEC61850 lab report: No. Schneider_VAL_Easergy P5M30__Ed2_RPT will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to Schneider Electric IEC61850 lab by Schneider Electric. The manufacturer's production process has not been assessed. This certificate does not imply that Schneider Electric IEC61850 lab has certified or approved any product other than the specimen tested

Shanghai, May 12, 2020



Chunyan YU
Verification Manager

Issued by:




Lingli LIU
IEC61850 Test Engineer

¹ Level B _ Tester lab with certified ISO 9001 Quality System

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0_rev4

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv10, sSrv12, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12, sDsN11, sDsN12
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr15, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop2b, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl13, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl6, sCtl16, sCtl27
12c: Enhanced Direct control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl13, sCtl14, sCtl16, sCtl26
12d: Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOe1, sSBOe2, sSBOes6, sSBOes8	sCtl6, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3, sTmN2
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	