

IEC 61850 Certificate Level A¹

Ref. No: 20TC200890

Issued to:

DAEWOONG ELECTRIC Co., Ltd.
Hwanggeumro 127beon gil 10, Yangchon-cup
Gimpo-si, Gyeonggi-do, 10048,
Republic of Korea

For the client system:

Gateway
DW-SPiN IEC 61850 Client GW
Version 1.0.0
DW-SPiN-SC2
Windows Server (2019)

Issued by:

Korea Electrotechnology Research Institute
111, Hanggaul-ro, Sangnok-gu, Ansan-si, Gyeonggi-do, 15588, Republic of Korea

The client system has not shown to be non-conforming to:
IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in substations.

The conformance test has been performed according to IEC 61850-10 and UCA IUG Conformance Test Procedures for Client System with IEC 61850-8-1 interface, revision 1.1 with TPCL version 1.2.3 with client system's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in < DW-SPiN IEC 61850 Client GW, v.1.0.0 >", "Model Implementation Conformance Statement for the IEC 61850 interface in < DW-SPiN IEC 61850 Client GW, v.1.0.0 >", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in < DW-SPiN IEC 61850 Client GW, v.1.0.0 >" and product's extra information for testing "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in < DW-SPiN IEC 61850 Client GW, v.1.0.0 >".


The following IEC 61850 conformance blocks are tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (22/22)	12a	Direct Control (7/7)
2	Data Sets (7/9)	12b	SBO Control (9/9)
2+	Data Set Definition (6/6)	12c	Enhanced Direct Control (7/7)
4	Setting Group Selection (4/4)	12d	Enhanced SBO Control (9/9)
4+	Setting Group Definition (2/2)	13	Time Synchronization (4/4)
5	Unbuffered Reports (18/18)	14	File Transfer (7/8)
6	Buffered Reports (22/22)		

This Certificate includes a summary of the test results as carried out at KERI in Republic of Korea with UniCA IED simulator version 5.29.06, Anvil 3.8.0.0 and UniCA 61850 analyzer version 5.34.02. This document has been issued for information purposes only, and the original paper copy of the KERI report: 20TC200890 will prevail.

The test has been carried out on one single specimen of the client system as referred above and submitted to KERI by DAEWOONG ELECTRIC Co., Ltd. The manufacturer's production process has not been assessed. This Certificate does not imply that KERI has approved any product other than the specimen tested.

Republic of Korea, November 16, 2020



D. J. Lee
Executive Director
High Voltage Evaluation Division



S. P. Ahn
Technical Manager

¹ Level A – Independent Tester with certified ISO 17025 Quality System

Applicable Test Procedures from the UCA International Users Group Device Test Procedures for Client System with IEC 61850-8-1 interface, version 1.1 with TPCL version 1.2.3

Conformance Block	Mandatory	Conditional
1: Basic Exchange	cAss1, cAss2, cAss3, cAss4, cAssN1, cAssN4, cAssN5, cAssN6	cAssN7 cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrvN1, cSrvN2, cSrvN3, cSrvN4, cSrvN5, cSrvN6
2: Data Sets		cDs1, cDs2, cDs3, cDs4, cDs5, cDsN1a, cDsN1b
2+: Data Sets Definition	cDsN4	cDs6a, cDs6b, cDs7a, cDs7b, cDsN5
4: Setting Group	cSg2, cSgN1	cSg1, cSg3
4+: Setting Group Definition	cSg3, cSg4	
5: Unbuffered Reporting	cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRpN2, cRpN3, cRpN7, cRpN8	cRp1, cRp2, cRp6, cRp7, cRpN1, cRpN4, cRpN5, cRpN6
6: Buffered Reporting	cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr12, cBrN2, cBrN3, cBrN7, cBrN8, cBrN9	cBr1, cBr2, cBr6, cBr7, cBr13, cBrN1, cBrN4, cBrN5, cBrN6
12a: Direct control	cCtl4, cCtlN1 cDOs1, cDOs2	cCtl1, cCtl2, cCtl3
12b: SBO control	cCtl4, cCtlN1 cSBOs1, cSBOs2, cSBOs3	cCtl1, cCtl2, cCtl3, cSBOs4
12c: Enhanced Direct Control	cCtl4, cCtlN1 cDOes1, cDOes2	cCtl1, cCtl2, cCtl3
12d: Enhanced SBO control	cCtl4, cCtlN1, cSBOes1, cSBOes2, cSBOes3	cCtl1, cCtl2, cCtl3 cSBOes4
13: Time sync	cTm1	cTm2, cTmN1, cTmN2
14: File transfer	cFt1, cFt2, cFt3, cFtN1, cFtN2	cFt4, cFt5