



IEC 61850 Certificate Level A¹

No. 21TC200086

Issued to:

ENTEC Electric & Electronic, Co., Ltd.
225-38 Choirubaekro, Bondgam-eup, Hwasung-city,
Gyeonggi-do, 18329, Republic of Korea

For the server product:

Controller
ETR606
Software version: 1.0
Firmware version: 1.0

Issued by:

Korea Electrotechnology Research Institute
111, Hanggaul-ro, Sangrok-gu, Ansan-si, Gyeonggi-do, 15588, Republic of Korea

The server product has not been shown to be non-conforming to:
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.3 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in <ETR606 v.1.0>", "Model Implementation Conformance Statement for the IEC 61850 interface in <ETR606 v.1.0>", "TISSUES Implementation Conformance Statement for the IEC 61850 interface in <ETR606 v.1.0>" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing for the IEC 61850 interface in <ETR606 v.1.0>".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

1	Basic Exchange (20/26)	9a	GOOSE Publish (8/13)
2	Data Sets (4/7)	9b	GOOSE Subscribe (18/20)
2+	Data Set Definition (24/24)	12a	Direct Control (5/19)
4	Setting Group Selection (4/4)	12b	SBO Control (11/28)
5	Unbuffered Reporting (21/23)	12c	Enhanced Direct Control (5/21)
6	Buffered Reporting (29/33)	12d	Enhanced SBO Control (13/29)
		13	Time Synchronization (4/7)
		14	File Transfer (5/8)

This certificate includes a summary of the test results as carried out at KERI in Republic of Korea with UniGrid v.1.7.1 with test suite Ed2_Server_TP2.0 and UniCA Analyzer v.5.34.02. This document has been issued for information purposes only, and the original paper copy of the KERI report: No. 21TC200086 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KERI by ENTEC Electric & Electronic, Co., Ltd. The manufacturer's production process has not been assessed. This certificate does not imply that KERI has certified or approved any product other than the specimen tested.

Republic of Korea, February 15, 2021

D. J. Lee
 Executive Director
 High Voltage Evaluation Division

S. P. Ahn
 Technical Manager

¹ Level A - Independent Test lab with certified ISO/IEC 17025 Quality System

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test
Procedures version 2.0.3

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sSrv6, sSrvN1e, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12, sDsN11, sDsN12
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr15
9a: GOOSE Publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1
9b: GOOSE Subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos13
12a Direct control	sCtl5, sCtl10, sDOs1, sDOs2	sCtl16
12b SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOs1, sSBOs2, sSBOs6	sCtl4, sCtl16
12c Enhanced Direct control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl16
12d Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl16, sCtl26
13 Time sync	sTm1, sTm2, sTmN1	sTmN2
14 File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	