

IEC 61850 Certificate Level A¹

Issued to:

Engineering Center Energoservice
44, Aviamotornaya street, Bld 1
Office 1A, Room 1
Moscow, 111024
Russian Federation

For the server product:

ESM-HV400-24-A2E4-02S
Energy Meter, Power Quality Analyzer and Multifunction
Transducer
With IO module ENMV-1 (ЭHМВ-1)
ESM software version: 1.0.0.0. rev.910+
ESM Hardware version: 3.1
ESM S/N: 1090
ENMV-1 S/N: 30103

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.4 with product's protocol, model and technical issue implementation conformance statements and the extra information for testing : "Multifunctional measuring device ESM IEC 61850 Conformance Statement ESM.422160.001 IEC61850 CS.Rev.03.2021"


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (20/26)	9a GOOSE Publish (12/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (19/20)
2+ Data Set Definition (24/24)	12a Direct Control (6/19)
5 Unbuffered Reporting (19/23)	12d Enhanced SBO Control (15/29)
6 Buffered Reporting (27/33)	13 Time Synchronization (3/7)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA 1.7.1 with test suite 1.0 dated 4-2-2021 and UniCA 61850 Analyzer 6.40.01. This document has been issued for information purposes only, and the archived DNV verification report No. 10280728-INC 21-2601 rev 1 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Energoservice. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, March 1, 2021



N.A. Heijker
Business Leader
Interoperability of Smart Power Systems

Issued by:




R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.4

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6, sSrv10, sSrv12, sSrv13
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12, sDsN11, sDsN12
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp10, sRp15, sRp17, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr10, sBr15, sBr17
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop5, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos13
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl15, sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl6, sCtl7, sCtl15, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	