



IEC 61850 Certificate Level A¹

Issued to:

Siemens Mobility GmbH Mozartstraße 33b D-91052 Erlangen Germany For the server product:

SITRAS MDC DC Protection Device and Controller Firmware version: V1.1.0

S/N: LBL2479944

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5 with product's protocol, model and technical issue implementation conformance statements and the extra information for testing: "SITRAS MDC IEC 61850 PIXIT, version 1.1.0, date 04/2021".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| 1 Basic Exchange (21/26) 2 Data Sets (4/7) | 9a GOOSE Publish (11/13) 9b GOOSE Subscribe (19/20) |
|---|--|
| 2+ Data Set Definition (24/24) | 12a Direct Control (5/19) |
| 5 Unbuffered Reporting (21/23) | 12d Enhanced SBO Control (12/29) |
| 6 Buffered Reporting (29/33) | 13 Time Synchronization (6/7) |
| | 14 File Transfer (5/8) |

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 1.8.0 with test suite 20210330 and UniCA 61850 Analyzer 6.40.01. This document has been issued for information purposes only, and the archived DNV verification report No. 10269611-INC 21-2916 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Siemens. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, June 8, 2021

N.A. Heijker
Business Leader

Interoperability of Smart Power Systems

DNV

Issued by:

R. Schimmel
Verification Manager

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

 $^{^{\}rm 1}\,\text{Level}\,\text{A}$ - Independent test lab with certified ISO 9001 Quality System





IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5

| Con | formance Block | Ma4datory | Conditional |
|------|-------------------------|--|---|
| 1: | Basic Exchange | sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, sSrvN4 | sAssN6, sSrv6, sSrv12, sSrvN1e, sSrvN3 |
| 2: | Data Sets | sDs1, sDs10a, sDsN1ae | sDs15 |
| 2+: | Data Set Definition | sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10 | sDs11, sDs12, sDsN11, sDsN12 |
| 5: | Unbuffered Reporting | sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8 | sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5 |
| 6: | Buffered Reporting | sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8 | sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr15 |
| 9a: | GOOSE publish | sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12 | sGop1, sGop6, sGopN1, sGopN2 |
| 9b: | GOOSE subscribe | sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6 | sGos4, sGos13 |
| 12a: | Direct control | sCtl5, sCtl10, sDOns1, sDOns2 | sCtl7 |
| 12d: | Enhanced SBO Control | sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8 | sCtl7, sCtl16 |
| 13: | Time sync | sTm1, sTm2, sTmN1 | sTm3, sTm5, sTmN2 |
| 14: | File transfer | sFt1, sFt2ab, sFt4, sFt5, sFtN1ab | |