

IEC 61850 Certificate Level A¹

Issued to:

Schneider Electric España, S.A.
C/ Charles Darwin s.n.
(Edificio Bogaris)
41092 Sevilla
Spain

For the server product:

Saitel DR: HUE with AB_DIDO and AB_AI
Remote Terminal Unit & Controller with high performance CPU,
digital inputs, digital outputs, and analog inputs module

Module:	SW version:	S/N:
HUE	11.07.01_2106221139	2044R1587248
AB_DIDO	-	1015A1001701
AB_AI	-	0510A1000039

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.4 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in Saitel DR; v2, July 14, 2021", "Model Implementation Conformance Statement for the IEC 61850 interface in Saitel DR; v2, July 14, 2021" and "TISSUES Implementation Conformance Statement for the IEC 61850 Edition 2 Client/Server Interface in Saitel DR; v2, July 14, 2021" and product's extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Edition 2.0 SERVER interface in Saitel DR; v2, June 23, 2021".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (20/26)	12a Direct Control (7/19)
2 Data Sets (4/7)	12b SBO Control (13/28)
5 Unbuffered Reporting (19/23)	12c Enhanced Direct Control (8/21)
6 Buffered Reporting (27/33)	12d Enhanced SBO Control (15/29)
9a GOOSE Publish (11/13)	13 Time Synchronization (3/7)
9b GOOSE Subscribe (19/20)	

This certificate includes a summary of the test results as carried out at DNV in Spain with UniGrid SA Simulator 1.8.0 with test suite Ed2_Server_TP_2.0_Develop_20210621.1 and UniCA 61850 Analyzer 6.40.01.0. This document has been issued for information purposes only, and the archived DNV verification report No. 10266325-INC 21-3190 rev 1 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Schneider Electric. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, July 23, 2021



N.A. Heijker
Business Leader
Interoperability of Smart Power Systems

Issued by:




R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.4

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6, sSrv9, sSrv10, sSrv12
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr8, sBr10, sBr11, sBr12, sBr15
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos13
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl15, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl6, sCtl7, sCtl15, sCtl16
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl14, sCtl15, sCtl16
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl6, sCtl7, sCtl15, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	