

## IEC 61850 Certificate Level A<sup>1</sup>

**Issued to:**

ARC Informatique  
2 avenue de la Cristallerie  
92310 Sèvres  
France

**For the client system:**

PcVue version 15.1.3  
Platform for IoT, SCADA, BMS & real time Data analytics  
Dell Precision Tower 3620  
Windows Server 2019 Standard

The client system has not been shown to be non-conforming to:

### IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.2 with client system's protocol, model and technical issue implementation conformance statements: "CimWay - IEC61850 Client PICS, revision 2.4", "CimWay - IEC61850 Client MICS, revision 2.2" and "CimWay - IEC61850 Client TICS, revision 2.2" and product's extra information for testing: "CimWay - IEC61850 Client PIXIT, revision 2.2".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (22/24)	12a Direct Control (7/9)
2 Data Sets (8/10)	12b SBO Control (9/11)
5 Unbuffered Reporting (21/24)	12c Enhanced Direct Control (7/9)
6 Buffered Reporting (25/28)	12d Enhanced SBO Control (9/11)
	13 Time Synchronization (3/4)
	14 File Transfer (4/8)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniCA 61850 IED Simulator version 6.31.01 and UniCA 61850 Analyzer 6.40.01. This document has been issued for information purposes only, and the archived DNV verification report No. 10298575-INC 21-3210 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by ARC Informatique. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, September 2, 2021



**N.A. Heijker**  
Business Leader  
Interoperability of Smart Power Systems

**Issued by:**




**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System  
Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Client Conformance Test Procedures version 1.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	cAss1, cAss2, cAss3, cAssN1, cAssN4, cAssN5, cAssN6	cAssN7 cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrv9, cSrv10, cSrvN1, cSrvN3, cSrvN4, cSrvN5, cSrvN6
2: Data Sets		cDs1, cDs2, cDs3, cDs5, cDs6, cDsN1a, cDsN1b, cDsN1c
5: Unbuffered Reporting	cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRp11, cRp13a, cRp14, cRp15, cRp19, cRpN2, cRpN5, cRpN6	cRp1, cRp2, cRp6, cRp7, cRp16, cRp18, cRpN1
6: Buffered Reporting	cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr13a, cBr14, cBr15, cBr19, cBr30, cBr31, cBrN2, cBrN5, cBrN6	cBr1, cBr2, cBr6, cBr7, cBr16, cBr18, cBr32, cBr33, cBrN1
12a: Direct Control	cCtl4, cCtl5, cDOns1, cDOns2	cCtl1, cCtl2, cCtl3
12b: SBO Control	cCtl4, cCtl5, cSBOns1, cSBOns2, cSBOns3	cCtl1, cCtl2, cCtl3, cSBOns4
12c: Enhanced Direct Control	cCtl4, cCtl5, cDOes1, cDOes2	cCtl1, cCtl2, cCtl3
12d: Enhanced SBO Control	cCtl4, cCtl5, cSBOes1, cSBOes2, cSBOes3	cCtl1, cCtl2, cCtl3, cSBOes4
13: Time sync	cTm1, cTmN1	cTm2
14: File transfer	cFt1, cFt3, cFtN1	cFt5