

IEC 61850 Certificate Level A¹

Page 1/2
No. 22-017346-01-1

Issued to:
NexChal Co., Ltd.
A-#502 PDC, 242,
Pangyo-ro, Bundang-gu,
Seongnam-si, Gyeonggi-do,
Republic of Korea

For the client system:
SCADA IEC 61850 FEP
NC61850FEP
Software Version 1.0
HW : HP ProLiant DL380p Gen8 HSTNS-5163
OS : Red Hat Enterprise Linux release 8.4
S/N : NC61850-01

Issued by: **KOREA TESTING LABORATORY**

**The CLIENT has not been shown to be non-conforming to:
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems in power utility automation**

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Client Test Procedures version 1.2 with product's protocol, model and technical issue implementation conformance statements: "NexChal_NC61850FEP_PICS_v.1.0", "NexChal_NC61850FEP_MICS_v.1.0", "NexChal_NC61850FEP_TICS_v.1.0" and product's extra information for testing: "NexChal_NC61850FEP_PIXIT_v.1.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| | | | |
|-----|-------------------------------|-----|-------------------------------|
| 1 | Basic Exchange (20/24) | 12b | SBO Control (9/11) |
| 2 | Data Sets (8/10) | 12c | Enhanced Direct Control (7/9) |
| 4 | Setting Group Selection (3/3) | 12d | Enhanced SBO Control (9/11) |
| 5 | Unbuffered Reporting (22/24) | 13 | Time Synchronization (4/4) |
| 6 | Buffered Reporting (26/28) | 14 | File Transfer (6/8) |
| 9 | GOOSE Control Block (2/2) | 15 | Service Tracking (5/17) |
| 12a | Direct Control (7/9) | | |

This certificate includes a summary of the test results as carried out at Seoul in the Republic of Korea with IEC 61850 Ed2 Virtual Server version 1 with test suite IEC 61850 Ed2 Client Conformance Verifier1.0 and KEPCO ANALYZER 1.0. This document has been issued for information purposes only, and the original paper copy of KTL report: No. TR-22-017346-01-1 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KTL by NexChal Co., Ltd. The manufacturer's production process has not been assessed. This certificate does not imply that KTL has certified or approved any product other than the specimen tested.

Seoul, may. 12. 2022

A. Han

Ah Han
Principal Engineer
Convergence Technology Center

Jin Young

Jinyong Kim
Chief Engineer
Convergence Technology Center

1 Level A - Independent Test lab with accredited ISO/IEC 17025 Quality System

Applicable Test Procedures from the UCA International Users Group Edition 2 Client Test Procedures version 1.2

| Conformance Block | Mandatory | Conditional |
|------------------------------|--|---|
| 1: Basic Exchange | cAss1, cAss2, cAss3, cAssN1, cAssN4, cAssN5 cAssN6 | cAssN7 cSrv1, cSrv2, cSrv3, cSrv4, cSrv5, cSrv6, cSrv7, cSrvN1, cSrvN3, cSrvN4, cSrvN5, cSrvN6 |
| 2: Data Sets | | cDs1, cDs2, cDs3, cDs5, cDs6, cDsN1a, cDsN1b, cDsN1c |
| 4: Setting Group Selection | cSg2, cSgN1 | cSg1 |
| 5: Unbuffered Reporting | cRp3, cRp4, cRp5, cRp8, cRp9, cRp10, cRp11, cRp13a, cRp14, cRp15, cRp19, cRpN2, cRpN5, cRpN6 | cRp1, cRp2, cRp6, cRp7, cRp16, cRp17, cRp18, cRpN1 |
| 6: Buffered Reporting | cBr3, cBr4, cBr5, cBr8, cBr9, cBr10, cBr11, cBr13a, cBr14, cBr15, cBr19, cBr30, cBr31, cBrN2, cBrN5, cBrN6 | cBr1, cBr2, cBr6, cBr7, cBr16, cBr17, cBr18, cBr32, cBr33, cBrN1 |
| 9: GOOSE control block | | cGcb1, cGcb2 |
| 12a: Direct control | cCtl4a, cCtl5a, cDOns1, cDOns2 | cCtl1a, cCtl2a, cCtl3a |
| 12b: SBO control | cCtl4b, cCtl5b, cSBOns1, cSBOns2, cSBOns3 | cCtl1b, cCtl2b, cCtl3b, cSBOns4 |
| 12c: Enhanced Direct Control | cCtl4c, cCtl5c, cDOes1, cDOes2 | cCtl1c, cCtl2c, cCtl3c |
| 12d: Enhanced SBO control | cCtl4d, cCtl5d, cSBOes1, cSBOes2, cSBOes3 | cCtl1d, cCtl2d, cCtl3d, cSBOes4 |
| 13: Time sync | cTm1, cTmN1 | cTm2, cTmN2 |
| 14: File transfer | cFt1, cFt3, cFtN1 | cFt2, cFt5, cFtN2 |
| 15: Service Tracking | | cTrk1, cTrk2, cTrk7, cTrk8, cTrk9 |