



IEC 61850 Certificate Level A¹

Issued to:

TOSHIBA Energy Systems & Solutions Corporation Power Systems Protection and Control Dept. Fuchu Complex, 1 TOSHIBA-Cho Fuchu-shi, Tokyo 183-8511 Japan

For the server product: GRW200 Line Differential Protection IEC 61850 Software version: G2M85002A Main Software version: GS2RWIM13001 Hardware: GRW200-11-1M1-12-LL-51-AA0 S/N: VNT1493FM0001

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5 with product's protocol, model and technical issue implementation conformance statements: "Protocol implementation conformance statement (PICS) of the IEC 61850 communication interface in G2 series IED, 6F2S1921, Ver. 0.3", "Model implementation conformance Statement (MICS) of the IEC 61850 Ed. 2 GRW200, 6F2S1975, Ver. 0.0" and "Tissues conformance statement (TICS) of the IEC 61850 Ed.2 communication interface in G2 series IED, 6F2S1920, Ver. 0.3" and the extra information for testing: "Protocol implementation extra information for testing (PIXIT) of the IEC 61850 communication interface in G2 series IED, 6F2S1875, Ver. 0.14".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

| 1 2 4 5 6 | Basic Exchange (24/26) Data Sets (4/7) Setting Group Selection (4/4) Unbuffered Reporting (22/23) Buffered Reporting (32/33) | 12a 12b 12c 12d 13 | Direct Control (6/18) SBO Control (12/27) Enhanced Direct Control (8/20) Enhanced SBO Control (14/28) Time Synchronization (4/7) |
|-----------------------|------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------|
| 6 | Buffered Reporting (32/33) | 13 | Time Synchronization (4/7) |
| 6 | Buffered Reporting (32/33) | 13 | Lime Synchronization (4/7) |
| 94 | | 14 | |
| 9b | GOOSE Subscribe (20/20) | 15 | Service Tracking (4/17) |

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 2.1.1 with test suite 20220506 and UniCA 61850 Analyzer 6.41.00. This document has been issued for information purposes only, and the archived DNV verification report No. 10360590-DSO 22-2896 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by TOSHIBA Energy Systems & Solutions Corporation. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, May 13, 2022

G. Akse Business Development Manager

Business Development Manager

Issued by:

DN\

mme erification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

UCA International Users Group P.O. Box 315, Shell Knob, MO 65747 USA

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Tel . +31 26 356 9111 Fax. +31 26 351 3683





IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5

| Conformance Block | | Mandatory | Conditional |
|-------------------|----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------|
| 1: | Basic Exchange | sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, sSrvN4 | sAssN6, sSrv6, sSrv9, sSrv10, sSrv12, sSrv13, sSrvN1e, sSrvN3 |
| 2: | Data Sets | sDs1, sDs10a, sDsN1ae | sDs15 |
| 4: | Setting Group Selection | sSg1, sSg3, sSgN1 | sSg11 |
| 5: | Unbuffered Reporting | sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8 | sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRp15, sRpN5 |
| 6: | Buffered Reporting | sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8 | sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr15, sBr23, sBr24 |
| 9a: | GOOSE publish | sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12 | sGop1, sGop6, sGopN1, sGopN2 |
| 9b: | GOOSE subscribe | sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6 | sGos4, sGos6b, sGos13 |
| 12a: | Direct control | sCtl5, sCtl10, sDOns1, sDOns2 | sCtl7, sCtl16 |
| 12b: | SBO control | sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6 | sCtl4, sCtl7, sCtl16 |
| 12c: | Enhanced Direct Control | sCtl5, sCtl10, sDOes1, sDOes2 | sCtl7, sCtl14, sCtl16, sCtl26 |
| 12d: | Enhanced SBO Control | sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8 | sCtl4, sCtl7, sCtl16, sCtl26 |
| 13: | Time sync | sTm1, sTm2, sTmN1 | sTm3 |
| 14: | File transfer | sFt1, sFt2ab, sFt4, sFt5, sFtN1ab | |
| 15: | Service tracking | | sTrk1, sTrk2, sTrk4, sTrk7 |