

CENTRAL POWER RESEARCH INSTITUTE



Prof. Sir C V Raman Road, PO Box 8066, Sadashivanagar PO, BANGALORE 560 080. I N D I A



IEC 61850 Certificate Level A1

No.: CPRIBLRMUADSASL22TC0006

Issued to:

M/s. GE T&D INDIA LIMITED 19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI – 600043, TAMIL NADU, INDIA For the server product:

Bus Differential System Type: MULTILIN B90

Model No.: B90U15HKHF8SH6DL8SN6TSXXU4LW7H

Serial No.: AA6C18001553 Hardware Version: B90

Software Version: UR Family Version 8.05

Issued by: CENTRAL POWER RESEARCH INSTITUTE, India

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.3 with product's protocol, model and technical issue implementation conformance statements: "PICS UR Family version 8.05; dated:18th September 2020", "MICS UR Family version 8.05; dated:18th September 2020" and product's extra information for testing: "PIXIT UR Family version 8.05; dated: 18th September 2020".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

1 Basic Exchange (25/26)

2 Data Sets (4/7)

4 Setting Group Selection (4/4)

5 Unbuffered Reporting (19/23)

6 Buffered Reporting (27/33)

9a GOOSE Publish (12/13)

9b GOOSE Subscribe (19/20)

12a Direct Control (5/19)

12b SBO Control (10/28)

13 Time Synchronization (5/7)

14 File Transfer (6/8)

This Certificate includes a summary of the test results as carried out at Central Power Research Institute (CPRI), Bangalore in India with Client Simulator UniGrid SA Simulator version 1.8.0 with test suit version Ed2_Server_TP_2.0_20211006.3 and UniCA 61850 analyzer version 6.41.00.0. This document has been issued for information purposes only, and the original paper copy of the CPRI report No.: CPRIBLRMUADSASL22T0006; dated 30 May, 2022 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to CPRI by M/s. GE T&D INDIA LIMITED, 19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI – 600043, TAMIL NADU, INDIA. The manufacturer's production process has not been assessed. This certificate does not imply that CPRI has certified or approved any product other than the specimen tested.

Bangalore; 30 May, 2022

(V Shivakumar)

Joint Director

(Pradish M) Test Engineer

¹ Level A – Independent Test lab with certified ISO/IEC 17025 Quality System. UCA International Users Group, P.O. Box 315, Shell Knob, MO 65747, USA







No.: CPRIBLRMUADSASL22TC0006

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.3

| Conformance Block | Mandatory | Conditional |
|----------------------------|--|---------------------------------------|
| 1: Basic Exchange | sAss1, sAss2, sAss3, sAss4, sAssN2, | sAssN6, sSrv6, sSrv9, sSrv10, sSrv12, |
| | sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, | sSrv13, sSrvN1e, sSrvN2, sSrvN3 |
| | sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, | |
| | sSrvN4 | |
| 2: Data Sets | sDs1, sDs10a, sDsN1ae | sDs15 |
| 4: Setting Group Selection | sSg1, sSg3, sSgN1 | sSg11 |
| 5: Unbuffered Reporting | sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, | sRp8, sRp10, sRp11, sRp12, sRp15, |
| | sRp14, sRp16, sRpN1, sRpN2, sRpN3, | sRpN5 |
| | sRpN4, sRpN8 | |
| 6: Buffered Reporting | sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, | sBr8, sBr10, sBr11, sBr12, sBr15 |
| | sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, | |
| | sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, | |
| | sBrN4, sBrN5, sBrN8 | |
| 9a: GOOSE publish | sGop2a, sGop3, sGop4, sGop9, sGop10, | sGop1, sGop5, sGop6, sGopN1, sGopN2 |
| | sGop11, sGop12 | AN II |
| 9b: GOOSE subscribe | sGos1, sGos2, sGos3, sGos5, sGos6a, | sGos4, sGos6b |
| | sGos7, sGos8, sGos9, sGos10, sGos11, | |
| | sGos12, sGosN1, sGosN2, sGosN3, | |
| | sGosN4, sGosN5, sGosN6 | |
| 12a Direct control | sCtl5, sCtl10, sDOns1, sDOns2 | sCtl13 |
| 12b SBO control | sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, | sCtl6 |
| | sSBOns1, sSBOns2, sSBOns6 | |
| 13 Time sync | sTm1, sTm2, sTmN1 | sTm3, sTm5 |
| 14 File transfer | sFt1, sFt2ab, sFt4, sFt5, sFtN1ab | sFt3 |

(V Shivakumar)
Joint Director

(Pradish M) Test Engineer

