



IEC 61850 Certificate Level B¹

No. 50745.644T.805

Issued to:

UK Grid Solutions Limited St. Leonards Building, Redhill Business Park, Stafford, ST16 1WT, United Kingdom For the server product:

MiCOM P40 Agile P44T Distance Protection relay Hardware version: M Software version 91B

Issued by:

Grid Automation Laboratories, UK Grid Solutions Limited

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement (PICS) for the IEC 61850 Edition 2 server interface in PICS Rev Px4x_PC2_EN_H", "Model Implementation Conformance Statement (MICS) for the IEC 61850 Edition 2 server interface in MICS Rev P44T-EN-MC2-E", "Technical Issues Conformance Statement (TICS) for the IEC 61850 Edition 2 server interface in TICS Rev P44T-EN-TC2-E.1" and extra information for testing "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 Edition 2 server interface in PIXIT Rev P44T-EN-PX2-E.2".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

i	executed test cuses/ total number of test cuses/.							
	1	Basic Exchange (24/26)	12a	Direct Control (8/19)				
	2	Data Sets (4/7)	12b	SBO Control (14/28)				
	4	Setting Group Selection (4/4)	12c	Enhanced Direct Control (11/21)				
	5	Unbuffered Reporting (21/23)	12d	Enhanced SBO Control (16/29)				
	6	Buffered Reporting (31/33)	13	Time Synchronization (4/7)				
	9a	GOOSE Publish (12/13)	14	File Transfer (7/8)				
	9b	GOOSE Subscribe (19/20)						

This certificate includes a summary of the test results as carried out at Stafford, United Kingdom with UniGrid SA version 1.8.0 with test suite 2.0 and UniCA 61850 Analyzer version 6.40.05.0. This document has been issued for information purposes only, and the original paper copy of the Grid Automation Laboratories report: No. 50745.644T.305 will prevail.

The tests have been carried out on one single specimen of the product as referred and submitted to Grid Automation Laboratories by UK Grid Solutions Limited. The manufacturer's production process has not been assessed. This certificate does not imply that Grid Automation Laboratories at UK Grid Solutions Limited has certified or approved any other product other than the specimen tested.

Stafford, 1 Aug 2022

Allen Millard

Grid Automation Laboratories Manager

Hazarath Volet

Grid Automation Laboratories Test Engineer

¹ Level B - Test lab with certified ISO 9001 Quality System. UCA Users Group, P.O. Box 315, Shell Knob, MO 65747, USA





IEC 61850 Certificate Level B

No. 50745.644T.805

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.5.

Conformance Block	Mandatory	Conditional
	sAss1, sAss2, sAss3, sAss4, sAssN2,	sAssN6, sSrv6, sSrv9, sSrv10, sSrv12,
1: Pasis Evehange	sAssN3, sAssN4, sAssN5, sSrv1, sSrv2,	sSrv13, sSrvN1e, sSrvN3
1: Basic Exchange	sSrv3, sSrv4, sSrv5, sSrv8,	
	sSrvN1abcdf, sSrvN4	
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4: Setting Group	sSg1, sSg3, sSgN1	sSg11
Selection		
	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9,	sRp8, sRp10, sRp11, sRp12, sRp13, sRP15,
5: Unbuffered Reporting	Rp14, sRP16, sRpN1, sRpN2, sRpN3,	sRp17, sRpN5
	sRpN4, sRpN8	
	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9,	sBr8, sBr10, sBr11, sBr12, sBr13, sBr15,
	sBr14, sBR16, sBr20, sBr21, sBr22,	sBr17, sBr23, sBr24
6: Buffered Reporting	sBr25, sBr26, sBr27, sBr28, sBr29,	
	sBrN1, sBrN2, sBrN3, sBrN4, sBrN5,	
	sBrN8	
0a. COOSE	sGop2a, sGop3, sGop4,sGop9,	sGop1,sGop5, sGop6, sGopN1, sGopN2
9a: GOOSE publish	sGop10, sGop11, sGop12	
	sGos1, sGos2, sGos3, sGos5, sGos6a,	sGos4, sGos6b
9b: GOOSE subscribe	sGos7, sGos8, sGos9, sGos10, sGos11,	
	sGos12, sGosN1, sGosN2, sGosN3,	
	sGosN4, sGosN5, sGosN6	
	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl13, sCtl15, sCtl16
12a: Direct control		
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11,	sCtl6, sCtl7, sCtl15, sCtl16, sCtl27
	sCtl25, sSBOns1, sSBOns2, sSBOns6	
	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl13, sCtl14, sCtl15, sCtl16,
12c: Enhanced Direct		sCtl26, sCtl28
Control		
	aCHE aCHO aCHO aCHO aCHO	actic actiz active active action action
	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6,	sCtl6, sCtl7, sCtl15, sCtl16, sCtl26, sCtl28
12d: Enhanced SBO		
control	sSBOes8	7
13: Time sync	sTm1, sTm2, sTmN1	sTm3