

IEC 61850 Certificate Level A¹

Issued to:

Siemens AG
Wernerwerkdammm 5
13629 Berlin
Germany

For the server product:

SIPROTEC 5 - 7VU85 High Speed Busbar Transfer with three IO202 modules
Firmware version: V09.40
Hardware version: 7VU85-DAAA-AA0-0AAAA0-A90211-13113B-EBD000-000AC0-CH1BA2-CB1CB3-CB1
SV Publish: F4000S1I4U4, F4800S1I4U4, F12800S8I4U4, F15360S8I4U4, F4800S2I16U16, F14400S6I12U12
SV Subscribe: F4000S1I4U4, F4800S1I4U4, F12800S8I4U4, F15360S8I4U4, F4800S2I16U16

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 with Amendment 1 Parts 6, 7-1, 7-2, 7-3, 7-4, 8-1, 9-2 and IEC 61869 First Edition Part 9

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 and the UCA International Users Group Edition 2 with Amendment 1 Server Test Procedures version 1.2 with product's protocol, tissues implementation conformance statements and extra information for testing: "SIPROTEC 5 PIXIT, PICS, TICS IEC 61850 Manual, V9.40 and higher, C53000-G5040-C013-D, Edition 01.2023", and model implementation conformance statement: "SIPROTEC Model Implementation Conformance Statement (MICS) According to IEC 61850, Device: x7VU85, Mapping version V09.40.01".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1a Basic Exchange (26/29)	11a SV publish (20/22)
2 Data Sets (4/7)	11b SV subscribe (22/22)
2+ Data Set Definition (24/24)	12a Direct Control (10/18)
3 Substitution (3/3)	12b SBO Control (18/28)
4 Setting Group Selection (5/5)	12c Enhanced Direct Control (12/20)
4+ Setting Group Definition (14/14)	12d Enhanced SBO Control (18/28)
5 Unbuffered Reporting (25/26)	13a Time Synchronization with SNTP (7/8)
6 Buffered Reporting (35/36)	13b Time Synchronization with PTP (4/4)
9a GOOSE publish (11/13)	14 File Transfer (5/8)
9b GOOSE subscribe (27/27)	15 Service Tracking (2/17)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 2.0.2 with test suite 20221110 and UniCA 61850 Analyzer 6.41.00. This document has been issued for information purposes only, and the archived DNV verification report No. 10380332-DSO 23-2511 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Siemens AG. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, January 9, 2023



G. Akse
Business Development Manager
Interoperability of Smart Power Systems

Issued by:




R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System UCA International Users Group P.O. Box 315, Shell Knob, MO 65747 USA
Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

IEC 61850 Certificate Level A

Applicable Server Test Procedures from the UCA International Users Group Edition 2 with Amendment 1 Server Test Procedures version 1.2

Conformance Block	Mandatory	Conditional
1a: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv9, sSrv10, sSrv11, sSrv12, sSrv13, sSrv15, sSrvN1e, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12, sDsN11, sDsN12
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11, sSg13
4+: Setting Group Definition	sSg2, sSg4, sSg6, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg5, sSg9, sSg14
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRp23, sRpN1, sRpN2, sRpN3, sRpN4, sRpN5, sRpN7, sRpN8, sRpN9	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp15, sRp17
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr23, sBr24, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN7, sBrN8, sBrN9, sBrN10	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr15, sBr17
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop6, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGos14, sGos15, sGos20, sGos21, sGos22, sGos23, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6, sGosN7	sGos4, sGos6b, sGos13
11a: Sampled Values publish	sSvp1, sSvp2, sSvp3, sSvp4, sSvp5, sSvp6, sSvp7, sSvp8, sSvp14, sSvp18	sSvp9, sSvp10, sSvp11, sSvp15, sSvp16, sSvp17, sSvp20, sSvp21, sSvp22, sSvp23
11b: Sampled Values subscribe	sSvs1, sSvs2, sSvs3, sSvs4, sSvs5, sSvs6, sSvs7, sSvs8, sSvs9, sSvs10, sSvs11, sSvs14, sSvs15, sSvs16, sSvsN1, sSvsN2, sSvsN3, sSvsN4, sSvsN5, sSvsN6	sSvs12, sSvs13
12a: Direct control	sCtl5, sCtl10, sDOs1, sDOs2	sCtl7, sCtl13, sCtl16, sCtl17, sCtl21, sCtl28
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOs1, sSBOs2, sSBOs6, sSBOs8	sCtl4, sCtl6, sCtl7, sCtl16, sCtl17, sCtl21, sCtl27, sCtl28
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl13, sCtl14, sCtl16, sCtl17, sCtl21, sCtl26, sCtl28
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl7, sCtl16, sCtl17, sCtl21, sCtl26, sCtl28
13a: Time sync SNTP	sTm1, sTm2, sTm7, sTmN1	sTm3, sTm4, sTm5
13b: Time sync PTP	sTmP1, sTmP2, sTmPN1	sTmP5
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	
15: Service tracking		sTrk7, sTrk17

Test case	Limitations and comments
sSvp17	Current clipping limit could not be reached
sSBOs8	Performed according to Redmine #6188