



IEC 61850 Certificate Level A¹

Issued to:

Siemens AG Wernerwerkdamm 5 13629 Berlin Germany For the server product:

SIPROTEC V4

7SJ80 Overcurrent protection Firmware version: 04.80.00

EN100 Communication Module V4.41

S/N: BF2302503443

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6 with product's protocol, extra information and technical issue implementation conformance statements: "SIPROTEC 4 SIPROTEC Compact, Reyrolle IEDs, EN100 Communication Module, IEC 61850, PIXIT, PICS, TICS, C53000-G1140-C385-3 Edition 05.2023" and the model information for testing: "Model Implementation Conformance Statement (MICS) according to IEC 61850, Mapping family 7SX8XX, Mapping version 1 revision 0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1	Basic Exchange (23/26)	9a	GOOSE Publish (11/13)
2	Data Sets (4/7)	9b	GOOSE Subscribe (19/21)
2+	Data Set Definition (24/24)	12a	Direct Control (5/18)
4	Setting Group Selection (4/4)	12c	Enhanced Direct Control (4/20)
5	Unbuffered Reporting (21/23)	12d	Enhanced SBO Control (16/28)
6	Buffered Reporting (31/33)	13	Time Synchronization (5/7)
		14	File Transfer (5/8)

This certificate includes a summary of the test results as carried out at DNV in The Netherlands with UniGrid SA Simulator 2.2.0 with test suite 20230309 and UniCA 61850 Analyzer 6.44.01. This document has been issued for information purposes only, and the archived DNV verification report No. 10424808-DSO 23-2821 rev 2 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV by Siemens AG. The manufacturer's production process has not been assessed. This certificate does not imply that DNV has approved any product other than the specimen tested.

Arnhem, May 16, 2023

G. Akse

Business Development Manager Interoperability of Smart Power Systems Issued by:

DNV

R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System UCA International Users Group P.O. Box 315, Shell Knob, MO 65747 USA

Copyright © DNV Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.





IEC 61850 Certificate Level A

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6

Conformance Block		Mandatory	Conditional
1:	Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrv8, sSrvN1abcdf, sSrvN4	sAssN6, sSrv6, sSrv9, sSrv10, sSrv12, sSrvN1e, sSrvN3
2:	Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+:	Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs11, sDs12, sDsN11, sDsN12
4:	Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5:	Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp16, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp15, sRpN5
6:	Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr16, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBr29, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr15, sBr23, sBr24
9a:	GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11, sGop12	sGop1, sGop6, sGopN1, sGopN2
9b:	GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGos8, sGos9, sGos10, sGos11, sGos12, sGos23, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos13
12a:	Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16
12c:	Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	
12d:	Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl7, sCtl16, sCtl21, sCtl26
13:	Time sync	sTm1, sTm2, sTmN1	sTm3, sTmN2
14:	File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

• 7SK80 Motor protection