

CENTRAL POWER RESEARCH INSTITUTE





IEC 61850 Certificate Level A



No.: CPRIBLRSGRL24TC0005

Issued to:

M/s. Minilec (India) Pvt. Ltd. S.No. 1073/1,2,3, Post - Pirangoot, Taluka - Mulshi, Dist. - Pune, Maharashtra, Pin - 412111, INDIA

For the server product:

ALARM ANNUNCIATOR Model: MBAS 0600

Serial No: 0D0001 Hardware Version: 1.0 Software Version: 1.0

Issued by: CENTRAL POWER RESEARCH INSTITUTE, India

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6 with product's protocol, model and technical issue implementation conformance statements: "PICS Version 2.0; dated: 28 November 2023", "MICS Version 2.0; dated: 28 November 2023", "TICS Version 2.0; dated: 28 November 2023" and product's extra information for testing: "PIXIT Version 2.0; dated: 28 November 2023".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

- Basic Exchange (18/26)
- Data Sets (3/7)
- 2+ Data Set Definition (24/24)

- Unbuffered Reporting (21/23)
- Buffered Reporting (29/33)
- 13 Time sync (3/7)

This Certificate includes a summary of the test results as carried out at Central Power Research Institute (CPRI), Bangalore in India with Client Simulator UniGrid SA Simulator version 2.2.1 with test suit version Ed2TP2.0.6_Ed2.1TP1.2_v2.2.1 and UniCA 61850 analyzer version 6.45.2.0. This document has been issued for information purposes only, and the original paper copy of the CPRI report No.: CPRIBLRSGRL24T0005; dated: 22 March, 2024 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to CPRI by M/s. Minilec (India) Pvt. Ltd. S.No. 1073/1,2,3, Post - Pirangoot, Taluka - Mulshi, Dist. - Pune, Maharashtra, Pin - 412111, INDIA. The manufacturer's production process has not been assessed. This certificate does not imply that CPRI has certified or approved any product other than the specimen tested.

Bangalore; 22 March, 2024

(Dr. Amit Jain) Additional Director

Test Engineer

¹ Level A – Independent Test lab with certified ISO/IEC 17025 Quality System. UCA International Users Group, P.O. Box 315, Shell Knob, MO 65747, USA







No.: CPRIBLRSGRL24TC0005

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 2.0.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAss4, sAssN2,	sAssN6, sSrv10
	sAssN3, sAssN4, sAssN5, sSrv1,	
	sSrv2, sSrv3, sSrv4, sSrv5, sSrv8,	
	sSrvN1abcdf, sSrvN4	
2: Data Sets	sDs1, sDs10a, sDsN1ae	
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7,	sDs11, sDs12, sDsN11, sDsN12
	sDs8, sDs9, sDs13, sDs14, sDsN1cd,	
	sDsN2, sDsN3, sDsN4, sDsN5, sDsN6,	
	sDsN7, sDsN8, sDsN9, sDsN10	
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9,	sRp6, sRp7, sRp8, sRp10, sRp11,
	sRp14, sRp16, sRpN1, sRpN2, sRpN3,	sRp12, sRp15, sRpN5
	sRpN4, sRpN8	
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9,	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12,
	sBr14, sBr16, sBr20, sBr21, sBr22,	sBr15
	sBr25, sBr26, sBr27, sBr28, sBr29,	
	sBrN1, sBrN2, sBrN3, sBrN4, sBrN5,	
	sBrN8	
13 Time sync	sTm1, sTm2, sTmN1	34-11-3-

Annit Jain

(Dr. Amit Jain)
Additional Director

(Pradish M) Test Engineer

