

## Issues

| #    | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject                                                                                                          | Updated             |
|------|---------|---------|----|--------|--------|----------|-------------|------------------------------------------------------------------------------------------------------------------|---------------------|
| 5917 | Server  | Issues  |    |        | Closed | Urgent   |             | 'Expected result' for some test cases of CB9b: GOOSE subscribe                                                   | 03/01/2024 09:55 AM |
| 6595 | Server  | Issues  |    |        | Closed | High     |             | Configuration and datamodel test cases not applicable for test equipment                                         | 03/01/2024 10:07 AM |
| 668  | Server  | Issues  |    |        | Closed | High     |             | MirrorBlockCommand state not used for LNs without direct process interface (sCtl28)                              | 06/14/2022 08:30 AM |
| 6674 | Server  | Issues  |    |        | Closed | Normal   |             | Discuss changes to submission form and Certificates                                                              | 03/01/2024 10:10 AM |
| 6658 | Server  | Issues  |    |        | Closed | Normal   |             | Certificate template page 1 and page 2 seems to be disconnected                                                  | 03/01/2024 10:09 AM |
| 6633 | Server  | Issues  |    |        | Closed | Normal   |             | sRp15, sBr15 test description contains doName="MMXU...", while MMXU is InClass, not doName                       | 03/01/2024 10:08 AM |
| 6614 | Server  | Issues  |    |        | Closed | Normal   |             | New DO required for routable GOOSE and SMV service tracking - 1701                                               | 03/01/2024 10:08 AM |
| 6598 | Server  | Issues  |    |        | Closed | Normal   |             | Using the same dataset in URCB, BRCB and GoCB                                                                    | 03/01/2024 10:08 AM |
| 6541 | Server  | Issues  |    |        | Closed | Normal   |             | sMdl15 allow SCL floating point value can have minor difference in DUT                                           | 03/01/2024 10:07 AM |
| 6519 | Server  | Issues  |    |        | Closed | Normal   |             | Need to be able to test 61850-7-420 (Ed2.1)                                                                      | 03/01/2024 10:07 AM |
| 6518 | Server  | Issues  |    |        | Closed | Normal   |             | Functional constraint object non-volatility ambiguous - TISSUE 1822                                              | 03/01/2024 10:06 AM |
| 6473 | Server  | Issues  |    |        | Closed | Normal   |             | Inconsistency in LPHD requirements - Tissue 1752                                                                 | 03/01/2024 10:06 AM |
| 6470 | Server  | Issues  |    |        | Closed | Normal   |             | SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692)                                | 03/01/2024 10:05 AM |
| 6453 | Server  | Issues  |    |        | Closed | Normal   |             | sSvs8 the minimum svID length 4chars is not right against test case sSvp14                                       | 03/01/2024 10:04 AM |
| 6291 | Server  | Issues  |    |        | Closed | Normal   |             | sGos13 - Remove/deprecate PIXIT Gs12                                                                             | 03/01/2024 10:04 AM |
| 6281 | Server  | Issues  |    |        | Closed | Normal   |             | Templates for Ed. 2.1 conformance statements                                                                     | 03/01/2024 10:04 AM |
| 6280 | Server  | Issues  |    |        | Closed | Normal   |             | sSBOes8 check Cancel consistency with SelectWithValue                                                            | 03/01/2024 10:04 AM |
| 6279 | Server  | Issues  |    |        | Closed | Normal   |             | sSBOs8 - Test and Check in Cancel after Select request                                                           | 03/01/2024 10:03 AM |
| 6278 | Server  | Issues  |    |        | Closed | Normal   |             | Test case sSBOes1, sDOes1 miss referring to PIXIT entries                                                        | 03/01/2024 10:03 AM |
| 6277 | Server  | Issues  |    |        | Closed | Normal   |             | sCtl4 (stSeld) shall be mandatory in Ed2 Amend 1                                                                 | 03/01/2024 10:02 AM |
| 6276 | Server  | Issues  |    |        | Closed | Normal   |             | sGop13 does not consider that dataset with maximumAttributes number of FCD may be too big for GOOSE              | 03/01/2024 10:02 AM |
| 6269 | Server  | Issues  |    |        | Closed | Normal   |             | sSrv9, sSrv10: change Table 3 to Table D.1 reference                                                             | 03/01/2024 10:01 AM |
| 6255 | Server  | Issues  |    |        | Closed | Normal   |             | ED2.0 TP2.0.6 has sGos23 but PIXIT template misses the entry Gs13 while in TP1.2 ED2.1 the Gs13 has Amd1 Ed only | 03/01/2024 10:01 AM |
| 6227 | Server  | Issues  |    |        | Closed | Normal   |             | sDoc5 GSESettings/SMVsettings apply for SendGOOSE/SMVmessage not SetGoCBValues/SetMsvCBValues                    | 03/01/2024 10:01 AM |
| 6214 | Server  | Issues  |    |        | Closed | Normal   |             | ED2 sCtl14 refer to PIXIT entry Ct16 which is a ED1 only PIXIT entry                                             | 03/01/2024 10:00 AM |
| 6213 | Server  | Issues  |    |        | Closed | Normal   |             | sSvsN1 - confRev-1 not possible for backwards config                                                             | 03/01/2024 10:00 AM |
| 6211 | Server  | Issues  |    |        | Closed | Normal   |             | TP1.2 Certificate tempalte makes sSvp12 mandatory while it shall be optional                                     | 03/01/2024 10:00 AM |
| 6210 | Server  | Issues  |    |        | Closed | Normal   |             | sSvs4 remove PIXIT entry Svs3                                                                                    | 03/01/2024 09:59 AM |

| #    | Project     | Tracker | ID | Source | Status | Priority | Standard(s) | Subject                                                                                          | Updated             |
|------|-------------|---------|----|--------|--------|----------|-------------|--------------------------------------------------------------------------------------------------|---------------------|
| 6203 | Server      | Issues  |    |        | Closed | Normal   |             | sSvs6 - Test configuration does not consider available bandwidth                                 | 03/01/2024 09:59 AM |
| 6198 | Server      | Issues  |    |        | Closed | Normal   |             | How to interpret SCL with Services element in the IED and in the AccessPoint?                    | 03/01/2024 09:59 AM |
| 6193 | Server      | Issues  |    |        | Closed | Normal   |             | sRpN5 does not test for the case where URCBs are association based (non-indexed).                | 03/01/2024 09:58 AM |
| 6192 | Server      | Issues  |    |        | Closed | Normal   |             | Polarity of neutral in WYE                                                                       | 03/01/2024 09:58 AM |
| 6188 | Server      | Issues  |    |        | Closed | Normal   |             | sSBOs8 does not consider PIXIT Ct13                                                              | 03/01/2024 09:58 AM |
| 6169 | Server      | Issues  |    |        | Closed | Normal   |             | verify IED can subscribe to GOOSE/SV from ServerAt accesspoint                                   | 03/01/2024 09:57 AM |
| 6157 | Server      | Issues  |    |        | Closed | Normal   |             | sCnf/sMdl not applicable for test equipment                                                      | 03/01/2024 09:57 AM |
| 5959 | Server      | Issues  |    |        | Closed | Normal   |             | sSvp3 remove random and allow synSourceID=TRUE for backwards compatible config                   | 03/01/2024 09:56 AM |
| 5958 | Server      | Issues  |    |        | Closed | Normal   |             | sTm2 allow a more accurate Time Accuracy as documented                                           | 03/01/2024 09:56 AM |
| 5954 | Server      | Issues  |    |        | Closed | Normal   |             | sGop10 detail test missing                                                                       | 03/01/2024 09:55 AM |
| 5948 | Server      | Issues  |    |        | Closed | Normal   |             | sSvp22 detail is missing in TP1.2 (editorial)                                                    | 03/01/2024 09:55 AM |
| 5914 | Server      | Issues  |    |        | Closed | Normal   |             | Verify that LPHD.Sim is not affected by LLN0.Beh                                                 | 03/01/2024 09:54 AM |
| 5913 | Server      | Issues  |    |        | Closed | Normal   |             | sSrvN1e and sSrvN3 change condition SCL FC=CF/DC/SP with valKind=Set                             | 03/01/2024 09:54 AM |
| 5912 | Server      | Issues  |    |        | Closed | Normal   |             | sSrv6 checking the read-only part is always applicable                                           | 03/01/2024 09:54 AM |
| 5910 | Server      | Issues  |    |        | Closed | Normal   |             | Need to test that IEDs support 1 Step and 2 Step clocks: IOP 2022                                | 03/01/2024 09:53 AM |
| 5907 | Server      | Issues  |    |        | Closed | Normal   |             | sCtI26 - Cancel a direct control object                                                          | 03/01/2024 09:53 AM |
| 5905 | Server      | Issues  |    |        | Closed | Normal   |             | sSrvN4 is mandatory, used SetDataValues service is optional in PICS and may not be not supported | 03/01/2024 09:53 AM |
| 5362 | Server      | Issues  |    |        | Closed | Normal   |             | sGop2 and sGop4 check minimum MinTime and minimum MaxTime                                        | 03/01/2024 09:52 AM |
| 5326 | Server      | Issues  |    |        | Closed | Normal   |             | sSBOes8 incorrectly requires addCause=blocked-by-mode                                            | 03/01/2024 09:49 AM |
| 652  | Server      | Issues  |    |        | Closed | Normal   |             | Publisher can use maximum number of dataset elements                                             | 03/01/2024 09:48 AM |
| 6566 | Server      | Issues  |    |        | Closed | Normal   |             | Description discrepancy LTMS between Source and Channels - 1859                                  | 11/28/2023 08:18 AM |
| 6564 | Server      | Issues  |    |        | Closed | Normal   |             | Functional constraint object non-volatility ambiguous - 1822                                     | 11/14/2023 09:06 AM |
| 6567 | Server      | Issues  |    |        | Closed | Normal   |             | Semantic of PMRI.StrInhTmm - 1856                                                                | 11/14/2023 09:05 AM |
| 6570 | Server      | Issues  |    |        | Closed | Normal   |             | RSYN Rel mandatory? - 1766                                                                       | 11/14/2023 09:04 AM |
| 6527 | SCL Tooling | Issues  |    |        | Closed | Normal   |             | ICT Ed2.1 Certificate template mismatches                                                        | 11/14/2023 08:36 AM |
| 6526 | SCL Tooling | Issues  |    |        | Closed | Normal   |             | Revision 0.7 (final draft) should be 1.0                                                         | 11/14/2023 08:35 AM |
| 6525 | SCL Tooling | Issues  |    |        | Closed | Normal   |             | Ed2.1 tTf4 and tTf5 expected result mismatch                                                     | 11/14/2023 08:35 AM |
| 6209 | Server      | Issues  |    |        | Closed | Normal   |             | When does the one packet with SmpCnt=0 is missing in step 2 of sSvsN6                            | 02/21/2023 08:14 AM |
| 5319 | Server      | Issues  |    |        | Closed | Normal   |             | T1782 sCtI7 addcause "inconsistent-parameters" when check=00 not-supported                       | 11/01/2022 08:28 AM |
| 5289 | Server      | Issues  |    |        | Closed | Normal   |             | Ed2.1 Server TP 1.1 Does not include 2.0 server PIXIT Gs12                                       | 07/27/2022 10:39 AM |

| #    | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject                                                                               | Updated             |
|------|---------|---------|----|--------|--------|----------|-------------|---------------------------------------------------------------------------------------|---------------------|
| 637  | Server  | Issues  |    |        | Closed | Normal   |             | sFt4 missing expected result for step 3 and 4                                         | 06/14/2022 08:29 AM |
| 635  | Server  | Issues  |    |        | Closed | Normal   |             | sTm7 mandatory?                                                                       | 06/14/2022 08:29 AM |
| 634  | Server  | Issues  |    |        | Closed | Normal   |             | sCnf11 allow "none" as well                                                           | 06/14/2022 08:28 AM |
| 616  | Server  | Issues  |    |        | Closed | Normal   |             | sCnf10 in Ed2 remove voltagelevel and bay name TEMPLATE                               | 06/14/2022 08:28 AM |
| 638  | Server  | Issues  |    |        | Closed | Normal   |             | sCtl28 typo tOpOK and opOK (should be tOpOk and opOk)                                 | 09/14/2021 06:50 AM |
| 639  | Server  | Issues  |    |        | Closed | Normal   |             | Boolean ASN.1 encoding 0x02 for MMS client/server                                     | 09/14/2021 06:50 AM |
| 642  | Server  | Issues  |    |        | Closed | Normal   |             | Blocked/Test-blocked does not impact CSWI->XCBR interface - Tissue Ready to Be Tested | 09/14/2021 06:48 AM |
| 678  | Server  | Issues  |    |        | Closed | Normal   |             | MirrorBlockCommand state not used for LNs without direct process interface (sCtl28)   | 09/14/2021 06:44 AM |
| 641  | Server  | Issues  |    |        | Closed | Normal   |             | Integrity will be buffered - Tissue Ready for Test Development                        | 03/02/2021 08:52 AM |
| 6657 | Server  | Issues  |    |        | Closed | Low      |             | Annex H certificate 9c missing (xx/xx)                                                | 03/01/2024 10:09 AM |
| 6491 | Server  | Issues  |    |        | Closed | Low      |             | Incorrect reference                                                                   | 03/01/2024 10:06 AM |
| 6320 | Server  | Issues  |    |        | Closed | Low      |             | Ct24 description uses not defined in the standard term: Internal Controllable Objects | 03/01/2024 10:04 AM |
| 6215 | Server  | Issues  |    |        | Closed | Low      |             | ED2 Amendment 1 TP1.2 Editorial - Change references to Table 54 -> Table 21           | 03/01/2024 10:00 AM |
| 657  | Server  | Issues  |    |        | Closed | Low      |             | Publish/subscribe enum with negative value                                            | 03/01/2024 09:49 AM |
| 656  | Server  | Issues  |    |        | Closed | Low      |             | Publish/subscribe enum with value > 127                                               | 03/01/2024 09:48 AM |